

## Rosalind Fazel

---

**From:** Richard.N.Walke@US.UL.com  
**Sent:** Thursday, April 17, 2008 7:10 PM  
**To:** Rosalind Fazel  
**Subject:** AC179 Comments

### *Comments on Criteria AC179.*

Richard N. Walke  
Underwriters Laboratories Inc.  
(847) 664 - 3084  
Richard.N.Walke@US.UL.com

### *Comments:*

It is requested that UL Standard 1479-94, Fire Tests of Through-Penetration Firestops, with revisions through August, 2000, be included as an alternate to ASTM E 814. This would require further revisions in Sections 1.3 and 3.3. ISO 6944, referenced in Sections 1.3 and 3.6, was revised on April 15, 2008. Consideration should be given to including the latest version of this Standard in AC179. Thanks for your consideration of these comments.