

Rosalind Fazel

From: robertnieminen@trinityerd.com
Sent: Tuesday, February 09, 2010 2:08 PM
To: Rosalind Fazel
Subject: AC75 Comments

Comments on Criteria AC75.

Robert Nieminen
Trinity|ERD
(203) 262-9245
robertnieminen@trinityerd.com

Comments:

The words "thermoplastic and" should be removed from Section 3.5. Inclusion is the result of proposed changes to AC75 back in 2004 through Peter Bahlo, along with the request to include ASTM D6878 as the physical properties specification for TPO single ply membranes. The applicant subsequently withdrew its request to include self-adhering thermoplastic membranes in the AC75 revision proposal (through Sabrina Pott), but maintained inclusion of ASTM D6878. While all references to self-adhering thermoplastic membranes were removed from the draft AC75 revisions, it was missed in Section 3.5.