

**From:** [ziegler@powers.com](mailto:ziegler@powers.com)  
**To:** [Rosalind Fazel](#)  
**Subject:** AC193 Comments  
**Date:** Wednesday, June 16, 2010 9:49:29 AM

---

*Comments on Criteria AC193.*

Mark Ziegler  
Powers Fasteners, Inc.  
914-235-6300  
[ziegler@powers.com](mailto:ziegler@powers.com)

*Comments:*

Proposal: Suggest staff and the committee consider the following language as replacement text for AC193, Annex A, A4.1.4 as the following: "The ability of the fixture to transfer loads to adjacent anchors shall be justified to the satisfaction of the code official by the design professional." Reason: The proposal is to change 'fixed element' to 'fixture' for clarification and tie the justification for the building official back to the design professional that would have an understanding of the design of redundant fastenings.



June 24, 2010

Mrs. Andra Hoermann-Gast  
Staff Engineer  
ICC Evaluation Services, Inc.  
5360 Workman Mill Road  
Whittier, CA 90601

**RE: Proposed Revisions to the Acceptance Criteria AC193**

Dear Mrs. Hoermann-Gast

This is regarding the proposed revisions detailed in your letter to Parties Interested in Evaluation Reports on Mechanical Anchors in Concrete Elements (**Subject AC193-0610-R1**) dated June 1, 2010. We have reviewed the revisions that were presented and are pleased to report that we are supportive of these changes.

Thank you for the opportunity to review these revisions. Please feel free to contact me should you have any questions.

Sincerely,

Chris La Vine  
Sr. Anchor Systems Engineer

cc: J. Dunagan