

**From:** [phillip.smith@fmapprovals.com](mailto:phillip.smith@fmapprovals.com)  
**To:** [Rosalind Fazel](#)  
**Subject:** AC75 Comments  
**Date:** Thursday, June 03, 2010 7:55:49 AM

---

*Comments on Criteria AC75.*

Phillip Smith  
FM Approvals  
781 255 4783  
[phillip.smith@fmapprovals.com](mailto:phillip.smith@fmapprovals.com)

*Comments:*

1.3.6.2 FM 4470-92, Approval Standard for Class 1 Roof Covers should now reference FM 4470-10. 1.3.9.1 ANSI/SPRI ES-1-03, Wind Design Standard for Edge Systems Used with Low-Slope Roofing Systems. Should now reference ANSI/SPRI/FM 4435-ES-1-2010 - Notre same reference is needed in 3.1.3