



Most Widely Accepted and Trusted

ICC-ES Evaluation Report

ICC-ES | (800) 423-6587 | (562) 699-0543 | www.icc-es.org

ESR-1539

Reissued 07/2017

This report is subject to renewal 07/2018.

DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES

SECTION: 06 05 23.13—NAILS

REPORT HOLDER:

INTERNATIONAL STAPLE, NAIL AND TOOL ASSOCIATION

**8735 WEST HIGGINS ROAD, SUITE 300
CHICAGO, ILLINOIS 60631**

EVALUATION SUBJECT:

POWER-DRIVEN STAPLES AND NAILS



Look for the trusted marks of Conformity!

"2014 Recipient of Prestigious Western States Seismic Policy Council (WSSPC) Award in Excellence"



A Subsidiary of

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.



ICC-ES Evaluation Report

ESR-1539

Reissued July 2017

Revised September 2017

This report is subject to renewal July 2018.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES

Section: 06 05 23.13—Nails

REPORT HOLDER:

INTERNATIONAL STAPLE, NAIL AND TOOL ASSOCIATION

8735 WEST HIGGINS ROAD, SUITE 300
CHICAGO, ILLINOIS 60631
(847) 375-6454

www.isanta.org

info@isanta.org

EVALUATION SUBJECT:

POWER-DRIVEN STAPLES AND NAILS

ADDITIONAL LISTEES:

“AMERICAN FASTENERS”—BRAND NAME

AMERICAN FASTENERS CO. LTD.

11175 INLAND AVENUE

JURUPA VALLEY, CALIFORNIA 91752

“MASTER FASTENERS”—BRAND NAME

BUILDING MATERIAL DISTRIBUTORS, INC.

225 ELM AVENUE

GALT, CALIFORNIA 95632

“FALCON”—BRAND NAME

FALCON FASTENERS REG'D

251 NANTUCKET BOULEVARD

TORONTO, ONTARIO M1P 2P2

CANADA

“FASCO,” “FASCO/BECK” AND “BECK FASTENER GROUP”—BRAND NAMES

FASCO AMERICA, INC.

105 INDUSTRIAL PARK DRIVE

MUSCLE SHOALS, ALABAMA 35661

“HITACHI”—BRAND NAME

HITACHI KOKI U.S.A., LTD.

1111 BROADWAY AVENUE

BRASELTON, GEORGIA 30517

“HUTTIG-GRIP”—BRAND NAME

HUTTIG BUILDING PRODUCTS

555 MARYVILLE UNIVERSITY DRIVE, SUITE 400

ST. LOUIS, MISSOURI 63141

“NAILPRO”—BRAND NAME

JAACO CORPORATION

18080 NE 68TH STREET, SUITE C130

REDMOND, WASHINGTON 98052

“PASLODE,” “LIGHTNING STRIKE” AND “DUO-FAST”—BRAND NAMES

PASLODE, AN ILLINOIS TOOL WORKS COMPANY

888 FOREST EDGE DRIVE

VERNON HILLS, ILLINOIS 60061-3105

“SPOTNAILS”—BRAND NAME

PEACE INDUSTRIES

1100 HICKS ROAD

ROLLING MEADOWS, ILLINOIS 60008

“GRIP-RITE,” “FAS’NERS UNLIMITED” AND “FITS RITE”—BRAND NAMES

PRIMESOURCE BUILDING PRODUCTS

1321 GREENWAY DRIVE

IRVING, TEXAS 75038

“SENCO” BRAND NAME

SENCO BRANDS, INC.

4270 IVY POINTE BOULEVARD

CINCINNATI, OHIO 45245

“SPECIALTY NAIL CO.,” “SPECIALTY FASTENERS”—BRAND NAMES

SPECIALTY FASTENING SYSTEMS, INC.

424 SOUTH BAGGETT

PRAIRIE GROVE, ARKANSAS 72753

“BOSTITCH” AND “DEWALT”—BRAND NAMES

STANLEY BLACK AND DECKER INC.

701 EAST JOPPA ROAD

TOWSON, MARYLAND 21286

1.0 EVALUATION SCOPE

Compliance with the following codes:

- 2015, 2012, 2009 and 2006 *International Building Code*® (IBC)
- 2015, 2012, 2009 and 2006 *International Residential Code*® (IRC)
- 2013 *Abu Dhabi International Building Code* (ADIBC)[†]

[†]The ADIBC is based on the 2009 IBC. 2009 IBC code sections referenced in this report are the same sections in the ADIBC.

Properties evaluated:

- Bending yield strength
- Compliance with prescriptive requirements of the IBC and IRC.
- Compliance with material requirements, dimensions and tolerances of ASTM F1667.
- Use in diaphragms, shear walls and braced walls.
- Fastening schedules which are alternates to those included in the codes.

2.0 USES

The nails and staples described in this report are used for engineered and nonengineered (prescriptive) structural connections.

3.0 DESCRIPTION**3.1 General:**

The fasteners recognized in this report are manufactured by and for the additional listees on this report, which are member companies of the International Staple, Nail and Tool Association (ISANTA). Appendix B of this report lists the fasteners recognized for each listee.

3.2 Staples:

Recognized staples are manufactured from plain or zinc-coated carbon steel wire or from stainless steel wire. Recognized staples comply with Table 59 of ASTM F1667 and have the characteristics shown in the table below. The staples have a minimum crown width of $\frac{7}{16}$ inch (11.1 mm) and a minimum leg length of $1\frac{1}{2}$ inches (38 mm). The staples are collated into strips and cohered with polymer coatings. Staple crown widths and leg lengths specified in this report are overall dimensions.

TABLE 3.2—STAPLE CHARACTERISTICS

STAPLE GAGE	NOMINAL WIRE DIAMETER (inch)	NOMINAL STAPLE WIDTH (inch)	MINIMUM BENDING MOMENT (lbf.-in.)
14	0.080	0.0855	4.3
15	0.0720	0.073	4.0
16	0.0625	0.064	3.6

For SI: 1 inch = 25.4 mm; 1 lbf-in = 0.113 N-m.

3.3 Nails:

Recognized nails are manufactured from plain steel wire, galvanized steel wire, or stainless steel wire. The nails have full round heads or modified round heads, such as offset heads, clipped heads ("D" heads) and notched heads, as shown in Figure 1. Nails have smooth or deformed (threaded) shanks. Deformed shanks may be annularly threaded (ring shank) or helically threaded (screw shank). Dimensional tolerances conform to ASTM F1667.

Nails designated as Metal Hardware Nails (MHN) are primarily intended for use with metal hardware (e.g. joist hangers, strap anchors, etc.), but may also be used in other engineered and prescriptive wood-to-wood or metal-to-wood connections. They have full round heads and smooth or ring shanks.

Nails with coating designated as EG are electro-galvanized in accordance with ASTM A641, Class 1. Nails with coating designated as HDG are hot-dip galvanized

and comply with the coating thickness requirement of ASTM A153, Class D. Both EG and HDG nails comply with the requirements of Section 10.1 of ASTM F1667.

Nails are collated and cohered into strips or coils for loading into a power driving tool. Typical recognized products are illustrated in Figure 1. The range of nail sizes addressed in this report is described in Table 1. See Appendix B for detailed nail descriptions including bending yield strength for products recognized for each listee.

3.4 Wood:

Wood members must be as described in the tables in this report. Sawn lumber must have an assigned specific gravity (SG) equal to or greater than what is required in the applicable table. Where use of engineered wood products is addressed in tables in this report, the products must have an equivalent specific gravity (ESG) equal to or greater than the SG that is addressed in the table, as shown in the applicable ICC-ES evaluation report for the engineered wood product.

3.5 Steel Side Plates:

Steel side plates must comply with ASTM A653 SS Grade 33 or 40, or with ASTM A36, as indicated in Table 3B. The steel must have a minimum base steel thickness as indicated in Table 3B. Holes in steel side plates must be predrilled or prepunched to allow for the installation of the nails.

4.0 DESIGN AND INSTALLATION**4.1 Design for Staples:**

4.1.1 Engineered Connections: Reference withdrawal design values for staples recognized in this report may be calculated in accordance with Section A2.3 of Appendix A. Reference withdrawal design values for select connections are shown in Table 4. The reference lateral design values for staples recognized in this report may be calculated in accordance with Section A2.2 of Appendix A.

4.1.2 Engineered Diaphragms and Shear Walls: The staples recognized in this report may be used in engineered diaphragms and shear walls, in accordance with the diaphragm and shear wall design tables in the IBC and Tables 5 through 9, when the staples comply with the requirements in the applicable table for gage, crown width and leg length. Diaphragm and shear wall deflection must be determined in accordance with Section A3.2.

4.1.3 Prescriptive Sheathing Attachments: The staples recognized in this report may be used to attach sheathing to wood framing as prescribed in the code tables referenced in Table 2, when the staples comply with the code requirements for gage, crown width and leg length.

4.2 Design for Nails:

4.2.1 Engineered Connections: The nails recognized in this report comply with the requirements of IBC Section 2303.6 and may be used in connections designed in accordance with the ANSI/AWC National Design Specification (NDS) for Wood Construction, using the specified minimum bending yield strength and the nominal diameter shown in Appendix B, as applicable. The yield mode equations and withdrawal equation shown in the NDS for nails are shown in Sections A1.2 and A1.3, respectively, of Appendix A to this report. Reference lateral design values for common wood-to-wood connections are shown in Table 3A and reference lateral design values for common metal-side-plate-to-wood connections are shown in Table 3B. Reference withdrawal design values for

common wood specific gravities are shown in Table 4. All reference design values must be multiplied by all applicable adjustment factors in accordance with the NDS.

4.2.2 Prescriptive Framing Connections: The nails may be used for prescriptive framing connections when the nails comply with the requirements in the applicable code for diameter and length. In addition, Table 10 shows alternative fastening designs for framing connections under the 2015 and 2012 IBC and IRC. The alternative fastener designs shown in Table 10 are summarized in Table 11.

4.2.3 Prescriptive Metal Hardware Connections: Nails designated as Metal Hardware Nails, as well as other nails recognized in this report as having full round heads and the applicable dimensions, may be used to attach metal hardware (e.g. joist hangers, foundation anchors) to wood framing members as prescribed in ICC-ES evaluation reports on metal hardware. Use of Metal Hardware Nails in diaphragms and shear walls is outside the scope of this report.

4.2.4 Engineered Diaphragms and Shear Walls: The nails may be used in shear walls and diaphragms designed in accordance with the ANSI/AWC Special Design Provisions for Wind and Seismic (SDPWS) and the tables in this report when they are of the required diameter and length indicated in the SDPWS or this report and when indicated in Appendix B as meeting the head area requirements for use in lateral force resisting assemblies for the applicable nail size.

Allowable shear values for diaphragms comprised of wood structural panels attached to wood framing are shown in Tables 5 and 6. Design of roof diaphragms must consider uplift due to wind.

Allowable shear values for shear walls comprised of wood structural panels attached directly to wood framing or over gypsum sheathing are shown in Tables 7 and 8. Design of exterior shear walls must also consider transverse (out-of-plane) loads on sheathing due to wind.

Allowable shear values for shear walls comprised of fiberboard sheathing, gypsum lath and plaster, gypsum sheathing, gypsum wallboard, metal or wire lath and plaster, or plywood siding applied directly to wood framing are shown in Table 9.

Diaphragm and shear wall deflection must be determined in accordance with Section A3.1.

4.2.5 Prescriptive Sheathing Attachments: Table 2 references the code tables where nails are prescribed for attaching sheathing to framing. Nails shown in Appendix B as meeting the head area ratio requirements for use in lateral force resisting assemblies may be used where the same nail type and size is prescribed in the referenced code tables.

4.3 Installation:

The nails must be installed in accordance with this report, the listee's published installation instructions, the approved plans, if applicable, and the applicable prescriptions in the code.

Nails used with metal hardware (joist hangers, truss plates, etc.) must be installed in accordance with the metal hardware manufacturer's instructions and any applicable ICC-ES evaluation report.

The nails described in this report are packaged for use in power tools. The nails must be installed using a tool recommended by the applicable listee. Individual nails may also be manually driven.

Edge distances, end distances, and spacings must be sufficient to prevent splitting of the wood. Installation into sawn lumber must be in accordance with the applicable requirements of 2015 NDS Section 12.1.6 (2012 NDS Section 11.1.6 for the 2012 IBC; 2005 NDS Section 11.1.5 for the 2009 and 2006 IBC).

Stainless steel nails and nails with coating designated as HDG comply with 2015 IBC Section 2304.10.5.1 (2012, 2009 and 2006 IBC Section 2304.9.5.1) and IRC Section R317.3 (2006 IRC Section R319.3) and may be used in preservative-treated and fire-retardant treated wood.

4.4 Special Inspection:

Periodic special inspection of nailing used in the construction of main windforce-resisting systems is required by 2015 IBC Section 1705.11.1 (2012 IBC Section 1705.10.1, 2009 IBC Section 1706.2) when the nail spacing is 4 inches (102 mm) or less. Periodic special inspection of nailing used in the construction of seismic force-resisting systems is required by 2015 IBC Section 1705.12.2 (2012 IBC Section 1705.11.2, 2009 and 2006 IBC Section 1707.3) when the nail spacing is 4 inches (102 mm) or less.

4.5 Use in Treated Lumber: In accordance with 2015 IBC Section 2304.10.5 (2012, 2009 and 2006 IBC Section 2304.9.5), stainless steel (SS) and hot-dip galvanized (HDG) nails listed in Appendix B, may be used in preservative-treated and fire-retardant-treated lumber. Use of nails listed in Appendix B as having a proprietary coating for installation in preservative-treated lumber in specific Exposure Conditions, is addressed in Appendix B or in applicable ICC-ES evaluation reports referenced in Appendix B. Nails and staples listed in Appendix B as bright must not be used in treated lumber. Use of nails and staples with other coatings in treated lumber is outside the scope of this report.

5.0 CONDITIONS OF USE

The nails and staples described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1** The nails and staples must be installed in accordance with this report, the listee's published installation instructions, the approved plans, if applicable, and the applicable prescriptions in the code. In the case of a conflict amongst these documents, the most restrictive requirements govern.
- 5.2** The fastener dimensions specified in the design tables in this report are minimum nominal dimensions. When fasteners larger than those specified are used for any application, consideration must be given to restrictions on edge distance and close spacing.
- 5.3** See Section 4.5 regarding use of staples and nails in treated wood.
- 5.4** The nails and staples described in Appendix B of this report are manufactured under quality control programs with inspections by ICC-ES.

6.0 EVIDENCE SUBMITTED

- 6.1** Data in accordance with the ICC-ES Acceptance Criteria for Nails (AC116), dated June 2014 (editorially revised April 2015).
- 6.2** Data in accordance with the ICC-ES Acceptance Criteria for Staples (AC201), dated February 2013 (editorially revised February 2015).

7.0 IDENTIFICATION

Containers of nails and staples must be identified with the name of one of the listees identified in this report, fastener

size (nail diameter and length or staple gage, width and length), finish/coating designation, country of origin and the evaluation report number (ESR-1539).

INDEX TO TABLES, FIGURES AND APPENDICES

Figure No.	Title	Page
1	Basic Fastener Styles	4

Table No.	Title	Page
1	Scope of Nail Sizes Addressed in This Report	5
2	Applicable Fastening Schedules in the Codes for Attachment of Sheathing to Framing	5
3A	Reference Lateral Design Values of Face Nailed Single Shear Connections of "2-by" Members to Other Members of the Same Species	6
3B	Reference Lateral Design Values of Face Nailed Single Shear Connections of Steel Side Members to Wood Members	7
4	Nail and Staple Reference Withdrawal Design Values	8

Horizontal Diaphragm Tables		
5	Allowable Shear for Wind or Seismic Loading for Wood Structural Panel Horizontal Diaphragms - Structural I Sheathing	9
6	Allowable Shear for Wind or Seismic Loading for Wood Structural Panel Horizontal Diaphragms - Rated Sheathing.....	10
	Footnote Explanations for Horizontal Diaphragm Tables 5 and 6	11

Vertical Shear Wall Tables		
7	Allowable Shear for Wind or Seismic Loading for Wood Structural Panel Shear Walls - Structural I Sheathing	12
8	Allowable Shear for Wind or Seismic Loading for Wood Structural Panel Shear Walls - Rated Sheathing.....	13
	Footnote Explanations for Shear Wall Tables 7 and 8.....	14
9	Allowable Shear for Wind or Seismic Loading for Shear Walls with Fiberboard Sheathing, Gypsum Lath, Gypsum Sheathing, Gypsum Wallboard, Lath and Plaster or Plywood Siding Over Wood Framing	15

Fastening Schedule for Framing Connections		
10	Fastening Schedule	16
11	Summary of Alternative Fastening Designs Recognized in Table 10.....	23

Appendix	Title	Page No.
A	Reference Design Information.....	24
B	Recognized Fasteners by Listee	28




FIGURE 1—BASIC FASTENER STYLES

TABLE 1—SCOPE OF NAIL SIZES ADDRESSED IN THIS REPORT¹

SHANK DIAMETER (inch)	DESCRIBED IN ASTM F1667				OTHERS				
	TYPE AND PENNYWEIGHT	LENGTH (inches)	HEAD DIAMETER (inch)	SHANK STYLE	COMMONLY AVAILABLE LENGTHS (inches)	SHANK STYLES	METAL HARDWARE NAILS ²		
							Lengths	Head Diameter	Shank Style
0.099	6d box	2	0.266	Smooth	2, 2 ¹ / ₄	Smooth, Ring, Screw	—	—	—
0.113	6d common	2	0.266	Smooth	2, 2 ³ / ₈ , 2 ¹ / ₂	Ring, Screw	—	—	—
	8d box	2 ¹ / ₂	0.297						
	8d cooler	2 ³ / ₈	0.281						
0.120	—	—	—	—	2 ³ / ₈ , 3, 3 ¹ / ₄	Smooth, Ring, Screw	—	—	—
0.131	8d common	2 ¹ / ₂	0.281	Smooth	2 ¹ / ₄ , 2 ³ / ₈ , 2 ¹ / ₂ , 3, 3 ¹ / ₄ , 3 ¹ / ₂ , 4	Smooth, Ring, Screw	1 ¹ / ₄ , 1 ¹ / ₂ , 2 ¹ / ₄ , 2 ³ / ₈ , 2 ¹ / ₂	0.281	Smooth, Ring
0.135	16d box	3 ¹ / ₂	0.344	Smooth	3 ¹ / ₂	Ring, Screw	—	—	—
0.148	10d common	3	0.312	Smooth	2 ¹ / ₂ , 3, 3 ¹ / ₄ , 3 ¹ / ₂	Ring, Screw	1 ¹ / ₄ , 1 ¹ / ₂ , 2 ¹ / ₂ , 3, 3 ¹ / ₂	0.281	Smooth, Ring
	12d common	3 ¹ / ₄	0.312						
0.162	16d common	3 ¹ / ₂	0.344	Smooth	3, 3 ¹ / ₂	Ring, Screw	2 ¹ / ₂ , 3, 3 ¹ / ₂	0.281	Smooth, Ring
0.180	—	—	—	—	5 ³ / ₈	Smooth	—	—	—
0.197	—	—	—	—	5 ³ / ₈	Smooth	—	—	—

For **SI**: 1 inch = 25.4 mm.

¹See Appendix B for recognized nail products for each listee.

²Nails intended for use with metal hardware such as joist hangers. See Appendix B of this report for associated designations on product labels.

TABLE 2—APPLICABLE FASTENING SCHEDULES IN THE CODES FOR ATTACHMENT OF SHEATHING TO FRAMING

CONSTRUCTION	CODE	TABLE NUMBER
Roof Sheathing Attachment	2015 IBC	2304.10.1
	2012, 2009 and 2006 IBC	2304.9.1
	2015, 2012, 2009 and 2006 IRC	R602.3(1), R602.3(2)
Wall Sheathing Attachment	2015 IBC	2304.10.1
	2012, 2009 and 2006 IBC	2304.9.1
	2015, 2012, 2009 and 2006 IRC	R602.3(1), R602.3(2), r602.3(3)
Floor Sheathing Attachment	2015 IBC	2304.10.1
	2012, 2009 and 2006 IBC	2304.9.1
	2015, 2012, 2009 and 2006 IRC	R602.3(1), R602.3(2)

TABLE 3A—REFERENCE LATERAL DESIGN VALUES OF FACE NAILED SINGLE SHEAR CONNECTIONS OF “2-BY” MEMBERS TO OTHER MEMBERS OF SAME SPECIES^{1,2,3,4,5,6}

NAIL DIMENSIONS		REFERENCE LATERAL DESIGN VALUES FOR SPECIFIC GRAVITIES OF: (lbf)			
Length (inches)	Nail Shank Diameter (inches)	0.42 (e.g., Spruce-pine-fir)	0.43 (e.g., Hem-fir)	0.50 (e.g., Douglas Fir-larch)	0.55 (e.g., Southern Pine)
3 ¹ / ₂	0.162	111	113	131	143
3 ¹ / ₄	0.148	100	102	118	128
3	0.148	100	102	118	128
3 ¹ / ₂	0.135	88	89	103	113
3 ¹ / ₄	0.131	82	84	97	106
3	0.131	82	84	97	106
2 ¹ / ₂	0.131	63	64	74	81
3 ¹ / ₄	0.120	69	71	81	89
3	0.120	69	71	81	89
2 ¹ / ₂	0.113	54	56	64	70
2 ³ / ₈	0.113	47	49	56	61
2 ¹ / ₄	0.099	36	36	42	46

For **SI**: 1 inch = 25.4 mm, 1 lbf = 4.45N, 1 psi = 6.89 kPa.

¹Design values are based on a normal load duration.

²Table values must be multiplied by all applicable adjustment factors in the NDS.

³Table is based upon a 1¹/₂-inch actual thickness of both attached member and receiving (“main”) member.

⁴Design values are for connections in which the nail shank is driven into the side grain with shank axis perpendicular to wood fibers. Tabulated values are based on a minimum fastener bending yield strength (F_{yb}) of 100,000 psi for nail diameters of 0.135 inch or less, and a minimum fastener bending yield strength (F_{yb}) of 90,000 psi for nail diameters of 0.148 and 0.162 inch.

⁵Calculations are based on a connection in which both members have the same specific gravity.

⁶Reference lateral design values apply to nails with either a smooth shank or a deformed shank.

TABLE 3B—REFERENCE LATERAL DESIGN VALUES OF FACE NAILED SINGLE SHEAR CONNECTIONS OF STEEL SIDE MEMBERS TO WOOD MEMBERS^{1,2,3,4}

STEEL SIDE MEMBER THICKNESS ⁶ (inch)	REFERENCE LATERAL DESIGN VALUES FOR SPECIFIC GRAVITIES ⁵ OF: (lbf)														
	0.42 (e.g., Spruce-pine-fir)					0.50 (e.g., Douglas Fir-larch)					0.55 (e.g., Southern Pine)				
	Nail Diameter (inch)					Nail Diameter (inch)					Nail Diameter (inch)				
	0.131	0.148	0.162			0.131	0.148	0.162			0.131	0.148	0.162		
	Nail Length (inches)					Nail Length (inches)					Nail Length (inches)				
	1 ¹ / ₂	2 ¹ / ₄ , 2 ³ / ₈ , 2 ¹ / ₂	1 ¹ / ₂	2 ¹ / ₂ , 3 3 ¹ / ₂	2 ¹ / ₂ , 3, 3 ¹ / ₂	1 ¹ / ₂	2 ¹ / ₄ , 2 ³ / ₈ , 2 ¹ / ₂	1 ¹ / ₂	2 ¹ / ₂ , 3, 3 ¹ / ₂	2 ¹ / ₂ , 3, 3 ¹ / ₂	1 ¹ / ₂	2 ¹ / ₄ , 2 ³ / ₈ , 2 ¹ / ₂	1 ¹ / ₂	2 ¹ / ₂ , 3 3 ¹ / ₂	2 ¹ / ₂ , 3, 3 ¹ / ₂
ASTM A653, Grade 33 Steel Side Plate															
0.033 - 0.036	82	82	97	97	117	94	94	112	113	136	102	102	122	123	147
0.044 - 0.048	83	83	97	98	117	95	95	112	114	136	102	102	122	124	148
0.055 - 0.060	84	84	97	99	118	96	96	113	115	138	104	104	122	125	149
0.068 - 0.075	86	86	98	102	121	98	98	114	118	140	106	106	123	127	151
0.097 - 0.105	93	93	103	108	127	105	105	118	125	147	113	113	128	135	159
0.127 - 0.134	102	102	109	118	137	115	115	126	135	157	124	124	135	146	170
0.171 - 0.179	116	116	123	137	157	132	132	138	154	177	142	142	149	166	190
0.228 - 0.240	111	116	119	140	168	127	132	137	160	192	138	144	148	174	209
ASTM A653, Grade 40 Steel Side Plate															
0.033 - 0.036	83	83	97	98	117	95	95	113	114	137	103	103	123	124	149
0.044 - 0.048	84	84	98	99	118	96	96	114	116	138	104	104	123	125	150
0.055 - 0.060	86	86	99	101	120	98	98	115	117	141	106	106	124	127	151
0.068 - 0.075	89	89	101	104	123	101	101	117	121	144	109	109	126	130	155
0.097 - 0.105	97	97	107	113	132	110	110	123	130	155	118	118	133	140	164
0.127 - 0.134	108	108	115	124	143	122	122	133	143	168	131	131	143	154	178
0.171 - 0.179	116	116	127	141	167	133	133	145	161	193	145	145	157	175	203
0.228 - 0.240	112	116	120	141	169	128	133	137	161	193	139	145	149	175	210
ASTM A36, Steel Side Plate															
0.250	111	117	117	139	169	128	134	137	162	194	139	145	157	186	222

For **SI**: 1 inch = 25.4 mm, 1 lbf = 4.45N, 1 psi = 6.89 kPa.

¹Design values are for normal load duration and must be multiplied by all applicable adjustment factors in the NDS.

²The tabulated values have been calculated in accordance with the Yield Mode Equations in Appendix A1.2. Dowel bearing strengths (F_{es}) used to calculate design values are 61,850 psi for ASTM A653, Grade 33; 75,600 psi for ASTM A653 Grade 40; and 87,000 psi for ASTM A36 side member material.

³Lateral design values are based on $F_{yb} = 100,000$ psi for 0.131-inch diameter nails; and $F_{yb} = 90,000$ psi for 0.148 and 0.162-inch diameter nails.

⁴Wood member must be of sufficient thickness for the nail point to be fully embedded in the wood.

⁵Specific Gravity values must be the assigned specific gravity from Table A or 2015 NDS Table 12.3.3A for the 2015 IBC (2012 NDS Table 11.3.3A for the 2012 IBC, 2005 NDS Table 11.3.2A for the 2009 and 2006 IBC) or the equivalent specific gravity for engineered wood products, as shown in an ICC-ES evaluation report.

⁶These thicknesses are base metal thicknesses and are based on typical steel thicknesses recognized in various ICC-ES evaluation reports for metal hardware and on the thicknesses addressed in Table 12P of the 2015 NDS.

TABLE 4—NAIL AND STAPLE REFERENCE WITHDRAWAL DESIGN VALUES^{1,2,3} (pounds-force per inch of penetration)

SPECIFIC GRAVITY ⁴	SMOOTH SHANK NAILS, DIAMETER IN INCHES									DEFORMED SHANK NAILS, DIAMETER IN INCHES						STAPLE GAGE AND DIAMETER ⁵ , in inches		
	0.099	0.113	0.120	0.131	0.135	0.148	0.162	0.180	0.197	0.099	0.113	0.120	0.131	0.135	0.148	16 gage	15 gage	14 gage
																0.063	0.072	0.080
0.31	7	8	9	10	10	11	12	13	15	8	9	10	11	11	12	9	11	12
0.35	10	11	12	13	14	15	16	18	20	11	12	13	14	15	16	13	14	16
0.36	10	12	13	14	14	16	17	19	21	11	13	14	15	16	17	13	15	17
0.37	11	13	14	15	16	17	19	21	23	12	14	15	17	17	19	14	17	18
0.38	12	14	15	16	17	18	20	22	24	13	15	16	18	18	20	15	18	20
0.39	13	15	16	17	18	19	21	24	26	14	16	17	19	19	21	16	19	21
0.40	14	16	17	18	19	21	23	25	28	15	17	18	20	21	23	17	20	22
0.41	14	17	18	19	20	22	24	27	29	16	18	20	21	22	24	19	21	24
0.42	15	18	19	21	21	23	26	28	31	17	20	21	23	23	26	20	23	25
0.43	16	19	20	22	23	25	27	30	33	18	21	22	24	25	27	21	24	27
0.44	17	20	21	23	24	26	29	32	35	19	22	23	26	26	29	22	26	28
0.46	19	22	24	26	27	29	32	36	39	21	25	26	29	29	32	25	29	32
0.47	20	24	25	27	28	31	34	38	41	22	26	28	30	31	34	26	30	33
0.49	22	26	28	30	31	34	38	42	46	25	29	31	33	34	38	29	33	37
0.50	24	28	29	32	33	36	40	44	48	26	30	32	35	36	40	30	35	39
0.51	25	29	31	34	35	38	42	46	50	27	32	34	37	38	42	32	37	41
0.55	30	35	37	41	42	46	50	56	61	33	38	41	45	46	50	39	45	50
0.58	34	40	42	46	48	52	57	64	70	38	44	47	51	53	58	44	51	57
0.67	49	57	61	66	68	75	82	91	100	54	63	67	73	75	83	63	73	81
0.68	51	59	63	69	71	78	85	95	104	56	65	69	76	78	86	66	76	84
0.71	57	66	70	77	79	87	95	106	115	63	73	77	84	87	95	73	84	94
0.73	61	71	75	82	85	93	102	113	124	67	78	83	91	93	102	79	90	101

For **SI**: 1 inch = 25.4 mm, 1 pound-force per inch = 0.175 N/mm.

¹Design values are based on a normal (10 year) duration of load.

²Table values must be multiplied by all applicable adjustment factors in the NDS.

³Withdrawal strengths are for fasteners driven perpendicular to the grain.

⁴Specific Gravity values must be the assigned specific gravity from Table A or NDS-15 Table 12.3.3A (NDS-12 Table 11.3.3A for the 2012 IBC, NDS-05 Table 11.3.2A for the 2009 and 2006 IBC) or the equivalent specific gravity for engineered wood products, as shown in an ICC-ES evaluation report.

⁵Values account for both staple legs.

**TABLE 5—ALLOWABLE SHEAR FOR WIND OR SEISMIC LOADING FOR WOOD STRUCTURAL PANEL HORIZONTAL DIAPHRAGMS
WITH FRAMING OF DOUGLAS FIR-LARCH OR SOUTHERN PINE AND STRUCTURAL I SHEATHING (plf)^{1,2,3,4,5,6,7,8,9}**

NOMINAL NAIL DIAMETER (inch) OR STAPLE GAGE	MINIMUM REQUIRED FASTENER LENGTH (inches)	MINIMUM WIDTH OF FRAMING MEMBER (inches)	BLOCKED DIAPHRAGMS								UNBLOCKED DIAPHRAGMS			
			FASTENER SPACING (inch) AT DIAPHRAGM BOUNDARIES (ALL CASES), AT CONTINUOUS PANEL EDGES PARALLEL TO LOAD (CASES 3, 4), AND AT ALL PANEL EDGES (CASES 5 & 6)								FASTENERS SPACED 6" MAX. AT SUPPORTED EDGES			
			6		4		2 1/2		2		Case 1 (No unblocked edges or continuous joints parallel to load)		All other configurations (Cases 2, 3, 4, 5 & 6)	
			Nail spacing at other panel edges (Cases 1, 2, 3 & 4)											
			6		6		4		3					
			Seismic	Wind	Seismic	Wind	Seismic	Wind	Seismic	Wind	Seismic	Wind	Seismic	Wind
3/8-inch Nominal Panel Thickness														
0.131 smooth or deformed	1 3/4	2 3	270 300	375 420	360 400	505 560	530 600	740 840	600 675	840 945	240 265	335 370	180 200	255 280
0.120 smooth or deformed	1 3/4	2 3	230 255	320 360	305 340	435 480	455 510	635 720	515 580	720 810	200 225	290 320	150 170	220 240
0.113 smooth or deformed	1 3/4	2 3	205 230	290 325	275 305	390 430	410 460	570 645	465 520	645 725	180 205	260 285	135 155	200 215
14, 15, 16 Gage	1 1/2 Leg Length	2 3	175 200	245 280	235 265	330 370	350 395	490 550	400 450	560 630	155 175	215 245	115 130	160 180
15/32-inch Nominal Panel Thickness														
0.148 smooth	2	2 3	320 360	445 505	425 480	595 670	640 720	895 1005	730 820	1025 1150	285 320	400 445	215 240	300 335
0.135 smooth or deformed	2	2 3	285 320	395 450	380 430	530 595	570 640	795 895	650 730	910 1020	255 285	355 395	195 215	270 300
0.131 smooth or deformed	2	2 3	270 305	375 425	360 405	505 565	540 605	755 845	610 685	865 970	240 270	340 375	180 200	255 285
0.120 smooth or deformed	2	2 3	230 260	325 370	310 350	435 490	465 520	650 730	525 590	745 835	205 230	290 325	155 175	220 245
0.113 smooth or deformed	2	2 3	210 235	295 335	280 315	395 440	420 470	590 660	475 535	675 755	185 210	265 295	140 155	200 220
14, 15, 16 Gage	1 1/2 Leg Length	2 3	175 200	245 280	235 265	330 370	350 395	490 550	400 450	560 630	155 175	215 245	120 130	160 180

See page 11 for footnote explanations and case diagrams.

**TABLE 6—ALLOWABLE SHEAR FOR WIND OR SEISMIC LOADING FOR WOOD STRUCTURAL PANEL HORIZONTAL DIAPHRAGMS
WITH FRAMING OF DOUGLAS FIR-LARCH OR SOUTHERN PINE AND RATED SHEATHING (plf)^{1,2,3,4,5,6,7,8,9}**

NOMINAL NAIL DIAMETER (inch) or STAPLE GAGE	MINIMUM REQUIRED FASTENER LENGTH (inches)	MINIMUM WIDTH OF FRAMING MEMBER (inches)	BLOCKED DIAPHRAGMS								UNBLOCKED DIAPHRAGMS			
			FASTENER SPACING (inch) AT DIAPHRAGM BOUNDARIES (ALL CASES), AT CONTINUOUS PANEL EDGES PARALLEL TO LOAD (CASES 3, 4), AND AT ALL PANEL EDGES (CASES 5 & 6)								FASTENERS SPACED 6" MAX. AT SUPPORTED EDGES			
			6		4		2 ¹ / ₂		2		Case 1 (No unblocked edges or continuous joints parallel to load)		All other configurations (Cases 2, 3, 4, 5 & 6)	
			Nail spacing at other panel edges (Cases 1, 2, 3 & 4)											
			6		6		4		3		Seismic	Wind	Seismic	Wind
Seismic	Wind	Seismic	Wind	Seismic	Wind	Seismic	Wind	Seismic	Wind	Seismic	Wind	Seismic	Wind	
³ / ₈ -inch Nominal Panel Thickness														
0.131 smooth or deformed	1 ³ / ₄	2 3	240 270	335 375	320 360	445 505	480 540	670 755	545 610	760 855	215 240	300 335	160 180	225 250
0.120 smooth or deformed	1 ³ / ₄	2 3	205 230	285 315	270 305	375 425	405 455	565 640	460 515	640 720	180 205	255 285	135 150	190 210
0.113 smooth or deformed	1 ³ / ₄	2 3	180 205	255 285	240 270	335 380	360 405	505 570	410 460	575 645	160 180	225 255	120 135	170 190
14, 15,16 Gage	1 ¹ / ₂ Leg Length	2 3	160 180	225 250	210 235	295 330	315 355	440 495	360 400	505 560	140 160	195 225	105 120	145 170
⁷ / ₁₆ -inch Nominal Panel Thickness														
0.131 smooth or deformed	2	2 3	255 285	360 400	340 380	475 530	505 570	705 800	575 645	805 900	230 255	320 355	170 190	235 265
0.120 smooth or deformed	2	2 3	215 240	305 340	290 325	405 450	430 485	600 680	490 550	685 765	190 215	270 300	145 160	200 225
0.113 smooth or deformed	2	2 3	195 215	275 305	260 290	360 405	385 435	540 610	440 490	615 685	175 195	245 270	130 145	180 200
14, 15, 16 Gage	1 ¹ / ₂ Leg Length	2 3	165 190	230 265	225 250	315 350	335 375	470 525	380 425	530 595	150 165	210 230	110 125	155 175
¹⁵ / ₃₂ -inch Nominal Panel Thickness														
0.148 smooth	2	2 3	290 325	405 455	385 430	540 605	575 650	805 910	655 735	920 1030	255 290	360 405	190 215	265 300
0.135 smooth or deformed	2	2 3	255 285	355 400	340 380	475 530	505 575	710 800	580 650	810 910	225 255	315 355	170 190	235 265
0.131 smooth or deformed	2	2 3	270 300	380 420	360 400	505 560	530 600	740 840	600 675	840 945	240 265	335 370	180 200	255 280
0.120 smooth or deformed	2	2 3	230 255	325 360	305 340	430 480	450510	630 715	510 575	715 805	205 225	285 315	155 170	220 240
0.113 smooth or deformed	2	2 3	205 230	290 320	275 305	385 430	405 460	570 645	460 520	645 725	185 205	255 285	140 155	195 215
14, 15, 16 Gage	1 ¹ / ₂ Leg Length	2 3	160 180	225 250	210 235	295 330	315 355	440 495	360 405	505 565	140 160	195 225	105 120	145 170
¹⁹ / ₃₂ -inch Nominal Panel Thickness ¹⁰														
0.148 smooth	2 ¹ / ₄	2 3	320 360	445 505	425 480	595 675	640 720	895 1010	730 820	1025 1150	285 320	400 445	215 240	300 335
0.135 smooth or deformed	2 ¹ / ₄	2 3	285 320	395 450	375 425	525 595	565 640	795 895	645 725	905 1020	255 285	355 395	190 215	265 295
0.131 smooth or deformed	2 ¹ / ₄	2 3	270 305	375 425	360 405	500 565	540 605	755 850	615 690	860 965	240 270	335 375	180 200	255 285
0.120 smooth or deformed	2 ¹ / ₄	2 3	235 260	325 365	310 350	435 490	465 525	650 735	530 595	745 835	205 235	290 325	155 175	220 245
0.113 smooth or deformed	2 ¹ / ₄	2 3	210 240	295 335	280 315	395 445	420 475	590 665	480 540	675 760	190 210	265 295	140 160	200 220
14, 15, 16 Gage	1 ¹ / ₂ Leg Length	2 3	175 200	245 280	235 265	330 370	350 395	490 555	400 450	560 630	155 175	215 245	115 130	160 180

See page 11 for footnote explanations and case diagrams.

FOOTNOTE EXPLANATIONS FOR HORIZONTAL DIAPHRAGM TABLES 5 AND 6

¹For **SI**: 1 inch = 25.4 mm, 1 plf = 14.6 N/m.

²Diaphragm construction using nails must be in accordance with Section 4.2.6 and 4.2.7 of the 2015 and 2008 AWC Special Design Provisions for Wind and Seismic (SPDWS), and diaphragm construction using staples must be in accordance with 2015 IBC Tables 2306.2(1) and 2306.2(2) (similar for earlier codes), as applicable.

³Tabulated values are for short-time loading due to wind or seismic. The tabulated seismic values must be reduced by 37 percent and 44 percent for normal and permanent load duration, respectively.

⁴The tabulated values are for fasteners installed in Douglas Fir-larch or Southern Pine framing. For framing of other species: (1) Find the assigned specific gravity for the applicable species of lumber (see Section A1.3). (2) For staples find the shear value from Table 5 (regardless of actual sheathing grade) and multiply the value by 0.82 for species with specific gravity of 0.42 or greater, or by 0.65 for all other species. (3) For nails find the shear value from the applicable table and multiply value by the Specific Gravity Adjustment Factor = $[1 - (0.5 - G)]$, where G = Specific Gravity of the framing lumber. This adjustment factor must not be greater than 1.

⁵Diaphragm deflection must be determined in accordance with Section A3.0.


⁶Structural I panels must comply with DOC PS1 or PS2. Rated Sheathing includes Sheathing and Single-Floor grades and must comply with DOC PS1 or PS2.

⁷Nails must be flat head nails denoted in Appendix B as meeting the head area ratio requirements for lateral force resisting assemblies. A deformed shank nail must have either a helical (screw) shank or an annular (ring) shank.

⁸Staples must have a $7/16$ -inch minimum crown width and must be installed with their crowns parallel to the long dimension of the framing members and must be driven flush with the surface of the sheathing.

⁹Space fasteners maximum 12" o.c. along intermediate framing members (6 in. o.c. when supports are spaced 48 inches o.c.).

¹⁰Tabulated values apply to wood structural panels up to $1\frac{1}{8}$ " in thickness, provided the nail penetration is at least $1\frac{1}{2}$ inches and the staple penetration is at least 1 inch.



CASE DIAGRAMS FOR HORIZONTAL DIAPHRAGM TABLES 5 AND 6

TABLE 7—ALLOWABLE SHEAR FOR WIND OR SEISMIC LOADING FOR WOOD STRUCTURAL PANEL SHEAR WALLS WITH FRAMING OF DOUGLAS FIR-LARCH OR SOUTHERN PINE AND STRUCTURAL I SHEATHING (plf)^{1,2,3,4,5,6,7,8,9,10,11}

NOMINAL NAIL DIAMETER (inch) OR STAPLE GAGE	MINIMUM NOMINAL FASTENER LENGTH (inches)		SEISMIC				WIND			
	Panels Applied Directly to Framing	Panels Applied Over 1/2 inch or 5/8 inch Gypsum Sheathing	Fastener Spacing at Panel Edges (inches)				Fastener Spacing at Panel Edges (inches)			
			6	4	3	2	6	4	3	2
3/8-inch Nominal Panel Thickness										
0.148 smooth	2	—	230	360	460	610	320	505	645	855
	—	2 1/2	280	430	550	730	390	600	770	1020
0.135 smooth or deformed	2	—	230	360	460	610	320	505	645	855
	—	2 1/2	250	380	485	645	345	530	680	900
0.131 smooth or deformed	1 3/4	—	230	360	460	610	320	505	645	855
	—	2 1/2	235	360	460	610	330	505	645	855
0.120 smooth or deformed	1 3/4	—	200	310	395	520	275	435	550	730
	—	2 1/2	200	310	395	520	280	430	550	725
0.113 smooth or deformed	1 3/4	—	180	280	355	470	245	390	495	655
	—	2 1/2	180	275	355	470	250	385	495	655
14, 15, 16 Gage	1 1/2	—	155	235	315	400	215	330	440	560
14, 15, 16 Gage	—	2	155	235	310	400	215	330	435	560
7/16-inch Nominal Panel Thickness										
0.148 smooth	2	—	260	395	505	670	355	550	705	935
	—	2 1/2	280	430	550	730	390	600	770	1020
0.135 smooth or deformed	2	—	260	395	505	670	355	550	705	935
	—	2 1/2	250	385	490	650	345	535	685	905
0.131 smooth or deformed	2	—	260	395	505	670	355	550	705	935
	—	2 1/2	235	365	465	615	330	505	650	860
0.120 smooth or deformed	2	—	225	340	435	580	305	475	610	805
	—	2 1/2	205	310	400	530	285	435	555	735
0.113 smooth or deformed	2	—	205	310	395	520	280	430	550	730
	—	2 1/2	170	260	330	440	235	360	460	610
14, 15, 16 Gage	1 1/2	—	170	260	345	440	240	365	485	615
14, 15, 16 Gage	—	2	155	235	310	400	215	330	435	560
15/32-inch Nominal Panel Thickness										
0.148 smooth	2	—	340	510	665	870	475	715	930	1215
	—	2 1/2	280	430	550	730	390	600	770	1020
0.135 smooth or deformed	2	—	305	455	590	775	425	635	825	1080
	—	2 1/2	250	385	490	650	350	535	685	905
0.131 smooth or deformed	2	—	280	430	550	730	390	600	770	1020
	—	2 1/2	240	365	465	615	330	505	650	860
0.120 smooth or deformed	2	—	245	375	475	630	340	520	665	880
	—	2 1/2	205	315	400	530	285	435	560	740
0.113 smooth or deformed	2	—	220	340	430	570	305	470	605	800
	—	2 1/2	185	285	365	480	260	395	510	670
14, 15, 16 Gage	1 1/2	—	185	280	375	475	260	390	525	665
14, 15, 16 Gage	—	2	155	235	300	400	215	330	420	560

See page 14 for footnote explanations.

TABLE 8—ALLOWABLE SHEAR FOR WIND OR SEISMIC LOADING FOR WOOD STRUCTURAL PANEL SHEAR WALLS WITH FRAMING OF DOUGLAS FIR-LARCH OR SOUTHERN PINE AND RATED SHEATHING (plf)^{1,2,3,4,5,6,7,8,9,10,11}

NOMINAL NAIL DIAMETER (inch) OR STAPLE GAGE	MINIMUM NOMINAL FASTENER LENGTH (inches)		SEISMIC				WIND			
	Panels Applied Directly to Framing	Panels Applied Over 1/2 inch or 5/8 inch Gypsum Sheathing	Fastener Spacing at Panel Edges (inches)				Fastener Spacing at Panel Edges (inches)			
			6	4	3	2	6	4	3	2
3/8-inch Nominal Panel Thickness										
0.148 smooth	2	—	220	320	410	530	305	445	575	740
	—	2 1/2	260	380	490	640	365	530	685	895
0.135 smooth or deformed	2	—	220	320	410	530	305	445	575	740
	—	2 1/2	230	335	430	560	320	465	600	785
0.131 smooth or deformed	1 3/4	—	220	320	410	530	305	445	575	740
	—	2 1/4	200	300	390	510	280	420	545	715
0.120 smooth or deformed	1 3/4	—	185	270	345	450	260	375	485	625
	—	2 1/2	170	255	330	430	235	355	460	605
0.113 smooth or deformed	1 3/4	—	200	300	390	510	280	420	545	715
	—	2 1/4	150	225	295	385	210	315	410	540
14, 15, 16 Gage	1 1/2	—	140	210	280	360	195	295	390	505
14, 15, 16 Gage	—	2	140	210	280	360	195	295	390	505
7/16-inch Nominal Panel Thickness										
0.148 smooth	2 1/2	—	240	350	450	585	335	490	630	820
	—	2 1/2	260	380	490	640	365	530	685	895
0.135 smooth or deformed	2	—	240	350	450	585	335	490	630	820
	—	2 1/2	230	335	435	565	320	465	605	790
0.131 smooth or deformed	2	—	240	350	450	585	335	490	630	820
	—	2 1/2	215	315	410	535	305	440	570	745
0.120 smooth or deformed	2	—	205	300	385	495	285	415	535	695
	—	2 1/2	185	270	345	455	260	375	485	635
0.113 smooth or deformed	2	—	185	265	345	445	255	375	480	625
	—	2 1/2	165	240	310	405	230	335	435	570
14, 15, 16 Gage	1 1/2	—	155	230	310	395	215	320	435	555
14, 15, 16 Gage	—	2	140	210	280	360	195	295	390	505
15/32-inch Nominal Panel Thickness										
0.148 smooth	2	—	310	460	600	770	435	645	840	1075
	—	2 1/2	260	380	490	640	365	530	685	895
0.135 smooth or deformed	2	—	275	405	530	680	385	570	740	950
	—	2 1/2	230	335	430	565	320	465	605	790
0.131 smooth or deformed	2	—	260	380	490	640	365	530	685	895
	—	2 1/2	215	315	410	535	305	440	570	745
0.120 smooth or deformed	2	—	220	325	420	545	310	450	585	765
	—	2 1/2	185	270	350	455	260	375	490	635
0.113 smooth or deformed	2	—	200	290	375	490	280	405	525	685
	—	2 1/2	165	245	315	410	235	340	440	575
14, 15, 16 Gage	1 1/2	—	170	255	335	430	240	355	470	600
14, 15, 16 Gage	—	2	140	210	280	360	195	295	390	505
19/32-inch Nominal Panel Thickness										
0.148 smooth	2 1/4	—	340	510	665	870	475	715	930	1215
0.135 smooth or deformed	2 1/4	—	300	450	590	770	420	635	825	1075
0.131 smooth or deformed	2 1/4	—	285	430	560	735	400	600	785	1025
0.120 smooth or deformed	2 1/4	—	245	370	485	635	345	520	675	885
0.113 smooth or deformed	2 1/4	—	225	335	440	575	315	470	615	800
14, 15, 16 Gage	1 3/4	—	185	280	375	475	260	390	525	665

See page 14 for footnote explanations.

FOOTNOTE EXPLANATIONS FOR SHEAR WALL TABLES 7 AND 8

¹For SI: 1 inch = 25.4 mm, 1 plf = 14.6 N/m.

²Shear wall construction using nails must be in accordance with Section 4.3.6 and 4.3.7 of the 2015 and 2008 AWC/AF&PA Special Design Provisions for Wind and Seismic (SPDWS), and shear wall construction using staples must be in accordance with 2015 IBC Table 2306.3(1) (similar for earlier codes), as applicable.

³Tabulated values are for short-time loading due to wind or seismic. The tabulated seismic values must be reduced by 37 percent and 44 percent for normal and permanent load duration, respectively.

⁴The tabulated values are for fasteners installed in Douglas Fir-larch or Southern Pine. For framing of other species: (1) Find the assigned specific gravity for species of lumber (see Section A1.3) (2) For staples find shear value from Table 7 (regardless of actual sheathing grade) and multiply value by 0.82 for species with specific gravity of 0.42 or greater, or 0.65 for all other species. (3) For nails find shear value from the applicable table and multiply by the following Specific Gravity Adjustment Factor = $[1 - (0.5 - G)]$, where G = Assigned Specific Gravity of the framing lumber. This adjustment factor must not be greater than 1.

⁵Shear wall deflection must be determined in accordance with Section A3.0.

⁶Structural I and Rated Sheathing panels must comply with DOC PS1 or PS2. Install panels either horizontally or vertically. All panel edges must be backed by framing members.

⁷In structures assigned to Seismic Design category D, E, or F, where the allowable shear design value exceeds 350 plf, all framing members receiving edge nailing from abutting panels must not be less than a single 3-inch nominal member. Panel joint and sill plate nailing must be staggered in all cases. See Section 4.3.6.4 of SDPWS, or 2006 IBC Section 2305.3.11 for sill plate size and anchorage requirements, as applicable.

⁸Space fasteners maximum 6 inches on center along intermediate framing members - Exception: When panel thickness is greater than $7/16$ -inch or studs are spaced less than 24 inches on center, space fasteners maximum 12 inches on center.

⁹Nails must be flat head nails denoted in Appendix B as meeting the head area ratio requirements for lateral force resisting assemblies. A deformed shank nail must have either a helical (screw) shank or an annular (ring) shank.

¹⁰Staples must have a $7/16$ -inch minimum crown width and must be installed with their crown parallel to the long dimension of the framing members, and must be driven flush with the surface of the sheathing.




¹¹The values for $3/8$ -inch and $7/16$ -inch panels applied directly to framing using nails may be increased to values shown for $15/32$ -inch-thick panels of the same panel grade, provided studs are spaced a maximum of 16 inches on center or panels are applied with long dimension across studs.

TABLE 9—ALLOWABLE SHEAR FOR WIND OR SEISMIC LOADING FOR SHEAR WALLS WITH FIBERBOARD SHEATHING, GYPSUM LATH, GYPSUM SHEATHING, GYPSUM WALLBOARD, LATH AND PLASTER OR PLYWOOD SIDING OVER WOOD FRAMING (plf)^{1,3,4}






SHEATHING MATERIAL	THICKNESS OF MATERIAL	WALL CONSTRUCTION	REQUIRED SPACING (inches on center)		SHEAR VALUE (plf)		FASTENER SPECIFICATIONS	COMMENTS	
			Panel Edges	Field	Seismic	Wind			
Fiberboard Sheathing	1/2"	Blocked	4	6	150	210	1 1/4" long, 16, 15 & 14 gage staple	Reference 2015 and 2012 IBC Table 2306.3(2) [2009 IBC Table 2306.6] for applicable notes	
			3		200	280			
			2		225	315			
			4		220	310	1 1/4" long, 1" crown, 16, 15 & 14 gage staple		
			3		290	405			
			2		325	455			
	25/32"	Blocked	4	6	150	210	1 1/2" long, 16, 15 & 14 gage staple		
			3		200	280			
			2		225	315			
			4		220	310	1 1/2" long, 1" crown, 16, 15 & 14 gage staple		
			3		290	405			
			2		325	455			
Gypsum Lath	3/8" + 1/2" Plaster	Unblocked	5		100		1 1/8" long, 3/4" crown, 16, 15 & 14 gage staple	Reference 2015 and 2012 IBC Table 2306.3(2) [2009 IBC Table 2306.6] for applicable notes	
Gypsum Sheathing	1/2" x 2' x 8'	Unblocked	4		75		1 3/4" long, 16, 15 & 14 gage staple		
	1/2" x 4'	Blocked			175 ²				
		Unblocked	7		100				
Gypsum Wallboard	1/2"	Unblocked	7		75 ²		1 1/2" long, 16, 15 & 14 gage staple		
					100				
			4		110 ²				
					125				
		Blocked	7		125				
			4		150				
	5/8"	Unblocked	7		115 ²		1 5/8" long, 16, 15 & 14 gage staple		
			4		145 ²				
		Blocked	7		145				
			4		175				
		Blocked two-ply	Base Ply - 9		250		1 5/8" long, 16, 15 & 14 gage staple		
			Face Ply - 7				2 1/4" long, 15 & 14 gage staple		
Expanded metal or woven wire lath and Portland cement plaster	7/8"	Unblocked	6" On Center @ Each Framing Member		180		7/8" long, 3/4" crown, 16, 15 & 14 gage staple		
Plywood Panel Siding Shear Walls with Framing of Douglas Fir-Larch or Southern Pine ²	3/8"	Panels Applied Directly To Framing	6	6	160	225	2 1/2 x 0.113 smooth	Reference SDPWS Table 4.3A for applicable notes	
			4		240	335			
			3		310	435			
			2		410	575			
			6	140	195	1 1/2" long, 16, 15 & 14 gage staple			
				4	210		295		
				3	280		390		
				2	360		505		
		Panels Applied Over 1/2" or 5/8" Gypsum Sheathing	6	6	160	225	3 x 0.131 smooth nail	Reference SDPWS Table 4.3B for applicable notes	
				4	240	335			
				3	310	435			
				2	410	575			
			6	6	140	195	2" long, 16, 15 & 14 gage staple		Reference 2015 and 2012 IBC Table 2306.3(1) [2009 IBC Table 2306.3] for applicable notes
				4	210	295			
				3	280	390			
				2	360	505			

For **SI**: 1 inch = 25.4 mm; 1 foot = 305 mm; 1 plf = 14.6 N/m.¹Shear values are based on maximum framing spacing of 16 inches on center, unless otherwise noted.²Shear values are based on maximum framing spacing of 24 inches on center.³Staples must have a minimum crown width of 7/16 inch, measured outside the legs, unless otherwise noted.⁴In addition to requirements presented above for fastening of shear walls all other requirements of the applicable model code (such as, but not limited to, conditions of use and modification of design values for certain Seismic Design Categories) pertaining to shear wall design and construction must be met.






TABLE 10—FASTENING SCHEDULE¹

CONNECTION DESCRIPTION	MINIMUM FASTENING REQUIREMENTS PRESCRIBED IN THE CODE								ALTERNATIVE FASTENING REQUIREMENTS					
	2012 IBC		2012 IRC		2015 IBC		2015 IRC							
	Table 2304.9.1		Table R602.3(1)		Table 2304.10.1		Table R602.3(1)							
	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)		
WALL FRAMING														
Double Studs (face nail)	Connection 9		Connection 12		Connection 8		Connection 8							
	@ 24" o.c.		@ 24" o.c.		@ 24" o.c.		@ 24" o.c.		@ 24" o.c.		@ 16" o.c.		@ 8" o.c.	
	1	16d box (3 1/2 x .135)	1	10d box (3 x .128)	1	16d com (3 1/2 x .162)	1	16d com (3 1/2 x .162)	1	16d com (3 1/2 x .162)	1	12d com (3 1/4 x .148)	1	8d com (2 1/2 x .131)
	@ 8" o.c.				@ 16" o.c.		@ 16" o.c.				1	10d com (3 x .148)	1	3 1/4 x .120
	1	3 x .131			1	3 x .131	1	3 x .131			1	16d box (3 1/2 x .135)	1	3 x .120
					1	10d box (3 x .128)	1	10d box (3 x .128)			1	3 1/4 x .131		
											1	3 x .131		
					At Braced Walls									
					Connection 9		Connection 9							
					@ 16" o.c.		@ 16" o.c.		@ 16" o.c.		@ 12" o.c.		@ 8" o.c.	
					1	16d com (3 1/2 x .162)	1	16d com (3 1/2 x .162)	1	16d com (3 1/2 x .162)	1	12d com (3 1/4 x .148)	1	3 1/4 x .120
											1	10d com (3 x .148)	1	3 x .120
					@ 12" o.c.		@ 12" o.c.				1	16d box (3 1/2 x .135)		
					1	3 x .131	1	3 x .131			1	3 1/4 x .131		
					1	16d box (3 1/2 x .135)	1	16d box (3 1/2 x .135)			1	3 x .131		
Abutting Studs at Corners and Intersections	Connection 23		Connection 8		Connection 8		Connection 8							
	@ 24" o.c.		@ 12" o.c.		@ 24" o.c.		@ 24" o.c.		@ 12" o.c.		@ 8" o.c.			
	1	16d com (3 1/2 x .162)	1	16d box (3 1/2 x .135)	1	16d com (3 1/2 x .162)	1	16d com (3 1/2 x .162)	1	16d com (3 1/2 x .162)	1	3 1/4 x .131		
									1	12d com (3 1/4 x .148)	1	3 x .131		
	@ 16" o.c.				@ 16" o.c.		@ 16" o.c.		1	10d com (3 x .148)	1	8d com (2 1/2 x .131)		
	1	3 x .131			1	3 x .131	1	3 x .131	1	16d box (3 1/2 x .135)	1	3 1/4 x .120		
					1	10d box (3 x .128)	1	10d box (3 x .128)			1	3 x .120		
					At Braced Walls									
					Connection 9		Connection 9							
					@ 16" o.c.		@ 16" o.c.		@ 16" o.c.		@ 12" o.c.		@ 8" o.c.	
					1	16d com (3 1/2 x .162)	1	16d com (3 1/2 x .162)	1	16d com (3 1/2 x .162)	1	12d com (3 1/4 x .148)	1	3 1/4 x .120
											1	10d com (3 x .148)	1	3 x .120
					@ 12" o.c.		@ 12" o.c.				1	16d box (3 1/2 x .135)		
					1	3 x .131	1	3 x .131			1	3 1/4 x .131		
					1	16d box (3 1/2 x .135)	1	16d box (3 1/2 x .135)			1	3 x .131		
Built-up header 2" to 2" w/ 1/2" spacer (face-nail)	Connection 14		Connection 9		Connection 10		Connection 10							
	@ 16" o.c.		@ 16" o.c.		@ 16" o.c.		@ 16" o.c.		@ 12" o.c.		@ 8" o.c.			
	1	16d com (3 1/2 x .162)	1	16d box (3 1/2 x .135)	1	16d com (3 1/2 x .162)	1	16d com (3 1/2 x .162)	1	16d com (3 1/2 x .162)	1	12d com (3 1/4 x .148)		
					@ 12" o.c.		@ 12" o.c.		1	16d box (3 1/2 x .135)	1	10d com (3 x .148)		
					1	16d box (3 1/2 x .135)	1	16d box (3 1/2 x .135)			1	3 1/4 x .131		
											1	3 x .131		
											1	3 1/4 x .120		
											1	3 x .120		
											1	3 x .120		
	each edge		each edge		each edge		each edge		each edge		each edge			






(Continued)

CONNECTION DESCRIPTION	MINIMUM FASTENING REQUIREMENTS PRESCRIBED IN THE CODE								ALTERNATIVE FASTENING REQUIREMENTS					
	2012 IBC		2012 IRC		2015 IBC		2015 IRC							
	Table 2304.9.1		Table R602.3(1)		Table 2304.10.1		Table R602.3(1)							
	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)
Continuous header to stud (toe-nail)	Connection 16		Connection 9		Connection 11		Connection 11							
 	4	8d com (2½ x .131)	4	8d box (2½ x .113)	4	8d com (2½ x .131)	4	8d com (2½ x .131)	3	16d com (3½ x .162)	4	8d com (2½ x .131)		
					4	10d box (3 x .128)	4	10d box (3 x .128)	4	12d com (¾ x .148)	5	¾ x .120		
							5	8d box (2½ x .113)	4	10d com (3 x .148)	5	3 x .120		
									4	16d box (3½ x .135)	6	8d box (2½ x .113)		
									4	¾ x .131	6	2⅝ x .113		
									4	3 x .131				
Double Top Plates to Each Other (face nail)	Connection 10a		Connection 13		Connection 12		Connection 12							
	@ 16" o.c.		@ 24" o.c.		@ 16" o.c.		@ 16" o.c.		@ 16" o.c.		@ 12" o.c.		@ 8" o.c.	
	1	16d box (¾ x .135)	1	10d box (3 x .128)	1	16d com (¾ x .162)	1	16d com (¾ x .162)	1	16d com (¾ x .162)	1	12d com (¾ x .148)	1	8d com (2½ x .131)
	@ 12" o.c.				@ 12" o.c.		@ 12" o.c.				1	10d com (3 x .148)	1	¾ x .120
	1	3 x .131			1	3 x .131	1	3 x .131			1	16d box (¾ x .135)	1	3 x .120
					1	10d box (3 x .128)	1	10d box (3 x .128)			1	¾ x .131		
											1	3 x .131		
Top Plate to Top Plate @ end joint (lap splice)	Connection 10b		Connection 14		Connection 13		Connection 13a							
	8	16d com (¾ x .162)	8	16d box (¾ x .135)	8	16d com (¾ x .162)	8	16d com (¾ x .162)	8	16d com (¾ x .162)	12	16d box (¾ x .135)		
	12	3 x .131			12	3 x .131	12	16d box (¾ x .135)	12	12d com (¾ x .148)	12	¾ x .131		
					12	10d box (3 x .128)	12	3 x .131	12	10d com (3 x .148)	12	3 x .131		
							12	10d box (3 x .128)						
	each side of joint		each side of joint		each side of joint		each side of joint		each side of joint		each side of joint			
							Connection 13b							
							12	16d box (¾ x .135)	10	16d com (¾ x .162)				
									12	12d com (¾ x .148)				
									12	10d com (3 x .148)				
							each side of joint		each side of joint					
Top Plate Overlap at Corners and Intersections (face nail)	Connection 13		Connection 19		Connection 18		Connection 17							
	2	16d com (¾ x .162)	2	10d box (3 x .128)	2	16d com (¾ x .162)	2	16d com (¾ x .162)	2	16d com (¾ x .162)	3	¾ x .131		
	3	3 x .131			3	3 x .131	3	3 x .131	3	12d com (¾ x .148)	3	3 x .131		
					3	10d box (3 x .128)	3	10d box (3 x .128)	3	10d com (3 x .148)	4	¾ x .120		
									3	16d box (¾ x .135)	4	3 x .120		






(Continued)

CONNECTION DESCRIPTION	MINIMUM FASTENING REQUIREMENTS PRESCRIBED IN THE CODE								ALTERNATIVE FASTENING REQUIREMENTS					
	2012 IBC		2012 IRC		2015 IBC		2015 IRC							
	Table 2304.9.1		Table R602.3(1)		Table 2304.10.1		Table R602.3(1)							
	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)
Sole (Bottom) Plate to Joist, Rim Joist, Band Joist or Blocking not at braced wall panel	Connection 6a		Connection 15		Connection 14		Connection 14							
	@ 16" o.c.		@ 16" o.c.		@ 16" o.c.		@ 16" o.c.		@ 16" o.c.		@ 12" o.c.		@ 8" o.c.	
	1	16d box (3 1/2 x .135)	1	16d box (3 1/2 x .135)	1	16d com (3 1/2 x .162)	1	16d com (3 1/2 x .162)	1	16d com (3 1/2 x .162)	1	12d com (3 1/4 x .148)		
											1	10d com (3 x .148)	1	3 1/4 x .120
	@ 8" o.c.				@ 12" o.c.		@ 12" o.c.				1	16d box (3 1/2 x .135)	1	3 x .120
	1	3 x .131			1	3 x .131	1	3 x .131			1	3 1/4 x .131		
				1	16d box (3 1/2 x .135)	1	16d box (3 1/2 x .135)			1	3 x .131			
Sole (Bottom) Plate to Joist, Rim Joist, Band Joist or Blocking at braced panel	Connection 6b		Connection 16		Connection 15		Connection 15							
	@ 16" o.c.		@ 16" o.c.		@ 16" o.c.		@ 16" o.c.		@ 16" o.c.		@ 12" o.c.			
	3	16d box (3 1/2 x .135)	3	16d box (3 1/2 x .135)	2	16d com (3 1/2 x .162)	2	16d com (3 1/2 x .162)	3	12d com (3 1/4 x .148)	2	16d com (3 1/2 x .162)		
	4	3 x .131			3	16d box (3 1/2 x .135)	3	16d box (3 1/2 x .135)	3	10d com (3 x .148)				
					4	3 x .131	4	3 x .131	3	16d box (3 1/2 x .135)				
									4	3 1/4 x .131				
									4	3 x .131				
									4	3 1/4 x .120				
									5	3 x .120				
Top or Sole (Bottom) Plate to Stud (end nail)	Connections 7 and 8b		Connection 18		Connections 17 and 16b		Connection 16b							
	2	16d com (3 1/2 x .162)	2	16d box (3 1/2 x .135)	2	16d com (3 1/2 x .162)	2	16d com (3 1/2 x .162)	3	16d com (3 1/2 x .162)	4	3 x .131		
	3	3 x .131			3	3 x .131	3	16d box (3 1/2 x .135)	3	12d com (3 1/4 x .148)	4	8d com (2 1/2 x .131)		
					3	10d box (3 x .128)	3	3 x .131	3	10d com (3 x .148)	4	3 1/4 x .120		
							3	10d box (3 x .128)	3	16d box (3 1/2 x .135)	4	3 x .120		
									4	3 1/4 x .131				
Stud to Top or Sole (Bottom) Plate (toe-nail)	Connection 8		Connection 17		Connection 16a		Connection 16a							
	4	8d com (2 1/2 x .131)	3	8d box (2 1/2 x .113)	4	8d com (2 1/2 x .131)	3	16d box (3 1/2 x .135)	3	16d com (3 1/2 x .162)	4	8d com (2 1/2 x .131)		
	4	3 x .131	2	16d box (3 1/2 x .135)	4	3 x .131	4	8d com (2 1/2 x .131)	4	12d com (3 1/4 x .148)	5	3 1/4 x .120		
					4	10d box (3 x .128)	4	3 x .131	4	10d com (3 x .148)	5	3 x .120		
							4	10d box (3 x .128)	4	16d box (3 1/2 x .135)	6	8d box (2 1/2 x .113)		
							4	8d box (2 1/2 x .113)	4	3 1/4 x .131	6	2 3/8 x .113		
									4	3 x .131	6	6d com (2 x .113)		
1" Diagonal Bracing to stud/plate (face-nail)	Connection 20		Connection 20		Connection 19		Connection 18							
	2	8d com (2 1/2 x .131)	2	8d box (2 1/2 x .113)	2	8d com (2 1/2 x .131)	2	8d com (2 1/2 x .131)	2	16d com (3 1/2 x .162)	2	8d com (2 1/2 x .131)		
	2	3 x .131			2	3 x .131	3	8d box (2 1/2 x .113)	2	12d com (3 1/4 x .148)	3	3 1/4 x .120		
					2	10d box (3 x .128)	2	10d box (3 x .128)	2	10d com (3 x .148)	3	3 x .120		
									2	16d box (3 1/2 x .135)	3	8d box (2 1/2 x .113)		
									2	3 1/4 x .131	3	2 3/8 x .113		
									2	3 x .131	4	2 1/4 x .099		





(Continued)

CONNECTION DESCRIPTION	MINIMUM FASTENING REQUIREMENTS PRESCRIBED IN THE CODE								ALTERNATIVE FASTENING REQUIREMENTS					
	2012 IBC		2012 IRC		2015 IBC		2015 IRC							
	Table 2304.9.1		Table R602.3(1)		Table 2304.10.1		Table R602.3(1)							
	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)
CEILING AND ROOF FRAMING														
Blocking Between Joists or Rafter to Top Plate (toe-nail)	Connection 11		Connection 1		Connection 1		Connection 1							
	3	8d com (2½ x .131)	3	8d box (2½ x .113)	3	8d com (2½ x .131)	3	8d com (2½ x .131)	3	16d com (3½ x .162)	3	3 x .131		
	3	3 x .131			3	3 x .131	3	3 x .131	3	12d com (¾ x .148)	3	8d com (2½ x .131)		
					3	10d box (3 x .128)	3	10d box (3 x .128)	3	10d com (3 x .148)	4	¾ x .120		
							4	8d box (2½ x .113)	3	16d box (3½ x .135)	4	3 x .120		
									3	¾ x .131	5	8d box (2½ x .113)		
					each end				each end		each end			
Ceiling Joist to Plate (toe-nail)	Connection 15		Connection 2		Connection 2		Connection 2							
	3	8d com (2½ x .131)	3	8d box (2½ x .113)	3	8d com (2½ x .131)	3	8d com (2½ x .131)	3	16d com (3½ x .162)	4	¾ x .120		
	5	3 x .131			3	10d box (3 x .128)	3	10d box (3 x .128)	3	12d com (¾ x .148)	4	3 x .120		
					3	3 x .131	3	3 x .131	3	10d com (3 x .148)	5	8d box (2½ x .113)		
									3	16d box (3½ x .135)	5	2⅝ x .113		
									3	¾ x .131	5	6d com (2 x .113)		
									3	3 x .131				
nail thru each side														
Ceiling Joist (not connected to parallel rafter - no thrust), laps over Partition	Connection 17		Connection 3		Connection 3		Connection 3							
	3	16d com (3½ x .162)	3	10d box (3 x .128)	3	16d com (3½ x .162)	3	16d com (3½ x .162)	3	16d com (3½ x .162)	4	¾ x .131		
	4	3 x .131			4	3 x .131	4	3 x .131	4	12d com (¾ x .148)	4	3 x .131		
					4	10d box (3 x .128)	4	10d box (3 x .128)	4	10d com (3 x .148)	5	¾ x .120		
									4	16d box (3½ x .135)	5	3 x .120		
Ceiling Joist to Parallel Rafters and at laps	Connection 18				Connection 4		Connection 4							
	See IBC Section 2308.1.4.1 and Table 2308.1.4.1				See IBC Section 2308.7.3.1 and Table 2308.7.3.1		See IRC Section R802.3.1, R802.3.2 & Table R802.5.1(9)							
Collar Tie to Rafter	Connection 26		Connection 4		Connection 5		Connection 5							
	3	10d com (3 x .148)	3	10d box (3 x .128)	3	10d com (3 x .148)	3	10d com (3 x .148)	3	16d com (3½ x .162)	4	3 x .131		
	4	3 x .131			4	10d box (3 x .128)	4	10d box (3 x .128)	3	12d com (¾ x .148)	5	8d com (2½ x .131)		
					4	3 x .131	4	3 x .131	3	10d com (3 x .148)	5	¾ x .120		
									4	16d box (3½ x .135)	5	3 x .120		
									4	¾ x .131	6	8d box (2½ x .113)		



(Continued)

CONNECTION DESCRIPTION	MINIMUM FASTENING REQUIREMENTS PRESCRIBED IN THE CODE								ALTERNATIVE FASTENING REQUIREMENTS					
	2012 IBC		2012 IRC		2015 IBC		2015 IRC							
	Table 2304.9.1		Table R602.3(1)		Table 2304.10.1		Table R602.3(1)							
	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)		
Roof Rafter to Plate (toe-nail)	Connection 19		Connection 5		Connection 6		Connection 6							
	3	8d com (2½ x .131)	3	10d com (3 x .148)	3	10d com (3 x .148)	3	10d com (3 x .148)	3	16d com (3½ x .162)	4	3 x .131		
	3	3 x .131	3	16d box (3½ x .135)	3	16d box (3½ x .135)	3	16d box (3½ x .135)	3	12d com (3¼ x .148)	4	8d com (2½ x .131)		
					4	3 x .131	4	3 x .131	3	10d com (3 x .148)	4	3¼ x .120		
					4	10d box (3 x .128)	4	10d box (3 x .128)	3	16d box (3½ x .135)	4	3 x .120		
									4	3¼ x .131				
	+ connectors per IBC Section 2308.10.1				+ connectors per IBC Section 2308.7.5				+ connectors per IBC		+ connectors per IBC			
ridge beam (end nail)	Connection 28b		Connection 6		Connection 7a		Connection 7b							
	2	16d com (3½ x .162)	4	16d box (3½ x .135)	2	16d com (3½ x .162)	2	16d com (3½ x .162)	3	16d com (3½ x .162)	4	3¼ x .131		
	3	3 x .131			3	3 x .131	3	16d box (3½ x .135)	4	16d com (3½ x .162)	4	3 x .131		
					3	10d box (3 x .128)	3	3 x .131	4	10d com (3 x .148)	5	3¼ x .120		
							3	10d box (3 x .128)	4	16d box (3½ x .135)	5	3 x .120		
Roof Rafter to 2 by ridge beam (toe nail)	Connection 28a		Connection 6		Connection 7b		Connection 7a							
	2	16d com (3½ x .162)	4	16d box (3½ x .135)	3	10d com (3 x .148)	3	10d com (3 x .148)	3	16d com (3½ x .162)	5	8d com (2½ x .131)		
	3	3 x .131			3	16d box (3½ x .135)	4	16d box (3½ x .135)	4	12d com (3¼ x .148)	6	3¼ x .120		
					4	3 x .131	4	3 x .131	4	10d com (3 x .148)	6	3 x .120		
					4	10d box (3 x .128)	4	10d box (3 x .128)	4	16d box (3½ x .135)	6	8d box (2½ x .113)		
									5	3¼ x .131	6	2⅜ x .113		
								5	3 x .131	6	6d com (2 x .113)			
Jack Rafter to Hip (toe nail)	Connection 27a		Connection 6		Connection 7b		Connection 7a							
	3	10d com (3 x .148)	4	16d box (3½ x .135)	3	10d com (3 x .148)	3	10d com (3 x .148)	3	16d com (3½ x .162)				
	4	3 x .131			3	16d box (3½ x .135)	4	16d box (3½ x .135)	4	12d com (3¼ x .148)				
					4	3 x .131	4	3 x .131	4	10d com (3 x .148)				
					4	10d box (3 x .128)	4	10d box (3 x .128)	4	16d box (3½ x .135)				
									5	3¼ x .131				
								5	3 x .131					
								5	8d com (2½ x .131)					
Jack Rafter to Hip (end nail)	Connection 27b		Connection 6		Connection 7a		Connection 7b							
	2	16d com (3½ x .162)	4	16d box (3½ x .135)	2	16d com (3½ x .162)	2	16d com (3½ x .162)	3	16d com (3½ x .162)				
	3	3 x .131			3	3 x .131	3	16d box (3½ x .135)	4	12d com (3¼ x .148)				
					3	10d box (3 x .128)	3	3 x .131	4	10d com (3 x .148)				
							3	10d box (3 x .128)	4	16d box (3½ x .135)				

(Continued)

CONNECTION DESCRIPTION	MINIMUM FASTENING REQUIREMENTS PRESCRIBED IN THE CODE								ALTERNATIVE FASTENING REQUIREMENTS					
	2012 IBC		2012 IRC		2015 IBC		2015 IRC							
	Table 2304.9.1		Table R602.3(1)		Table 2304.10.1		Table R602.3(1)							
	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)		
FLOOR FRAMING														
Joist to Sill or Girder (toe-nail)	Connection 1		Connection 24		Connection 22		Connection 21							
	3	8d com (2 1/2 x .131)	3	8d box (2 1/2 x .113)	3	8d com (2 1/2 x .131)	3	8d com (2 1/2 x .131)	3	16d com (3 1/2 x .162)	3	8d com (2 1/2 x .131)		
	3	3 x .131			3	3 x .131	3	3 x .131	3	12d com (3 1/4 x .148)	4	3 1/4 x .120		
					3	10d box (3 x .128)	3	10d box (3 x .128)	3	10d com (3 x .148)	4	3 x .120		
							4	8d box (2 1/2 x .113)	3	16d box (3 1/2 x .135)	5	8d box (2 1/2 x .113)		
									3	3 1/4 x .131	5	2 3/8 x .113		
									3	3 x .131	5	6d com (2 x .113)		
Rim Joist to Top Plate (toe-nail)	Connection 12		Connection 25		Connection 23		Connection 22							
	6" o.c.		6" o.c.		6" o.c.		4" o.c.		@ 6" o.c..		@ 4" o.c.		@ 3" o.c.	
	1	8d com (2 1/2 x .131)	1	8d box (2 1/2 x .113)	1	8d com (2 1/2 x .131)	1	8d box (2 1/2 x .113)	1	16d com (3 1/2 x .162)	1	3 1/4 x .120	1	2 x .113
	1	3 x .131			1	3 x .131	6" o.c.		1	12d com (3 1/4 x .148)	1	3 x .120	1	2 1/4 x .099
					1	10d box (3 x .128)	1	8d com (2 1/2 x .131)	1	10d com (3 x .148)	1	8d box (2 1/2 x .113)		
							1	3 x .131	1	16d box (3 1/2 x .135)	1	2 3/8 x .113		
							1	10d box (3 x .128)	1	3 1/4 x .131				
Joist to Band Joist (face nail)	Connection 29				Connection 29		Connection 26							
	3	16d com (3 1/2 x .162)			3	16d com (3 1/2 x .162)	3	16d com (3 1/2 x .162)	4	3 1/4 x .131				
	4	3 x .131			4	3 x .131	4	12d com (3 1/4 x .148)	4	3 x .131				
					4	10d box (3 x .128)	4	10d com (3 x .148)	6	3 1/4 x .120				
							4	16d box (3 1/2 x .135)	6	3 x .120				
Built up Girder or Beam	Connection 24		Connection 30		Connection 27		Connection 27							
	face nail at top and bottom staggered on opposite side:								face nail at top and bottom staggered on opposite side:					
	@ 32" o.c.		@ 32" o.c.		@ 32" o.c.		@ 32" o.c.		@ 32" o.c.		@ 24" o.c.		@ 16" o.c.	
	1	20d com (4 x .192)	1	10d box (3 x .128)	1	20d com (4 x .192)	1	20d com (4 x .192)	1	20d com (4 x .192)	1	16d com (3 x .162)	1	3 1/4 x .120
	@ 24" o.c.				@ 24" o.c.		@ 24" o.c.				1	12d com (3 1/4 x .148)	1	3 x .120
	1	3 x .131			1	3 x .131	1	3 x .131			1	10d com (3 x .148)		
					1	10d box (3 x .128)	1	10d box (3 x .128)			1	16d box (3 1/2 x .135)		
											1	3 1/4 x .131		
											1	3 x .131		
	AND at each end or splice (face nail):								AND at each end or splice (face nail):					
	2	20d com (4 x .192)	2	10d box (3 x .128)	2	20d com (4 x .192)	2	20d com (4 x .192)	2	20d com (4 x .192)	3	3 1/4 x .131		
	3	3 x .131			3	3 x .131	3	3 x .131	3	16d com (3 1/2 x .162)	3	3 x .131		
					3	10d box (3 x .128)	3	10d box (3 x .128)	3	12d com (3 1/4 x .148)	3	3 1/4 x .120		
									3	10d com (3 x .148)	4	3 x .120		
									3	16d box (3 1/2 x .135)				

(Continued)

CONNECTION DESCRIPTION	MINIMUM FASTENING REQUIREMENTS PRESCRIBED IN THE CODE								ALTERNATIVE FASTENING REQUIREMENTS					
	2012 IBC		2012 IRC		2015 IBC		2015 IRC							
	Table 2304.9.1		Table R602.3(1)		Table 2304.10.1		Table R602.3(1)							
	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)	#	Nail Size (Type, inch)		
Ledger Strip (face nail)	Connection 30		Connection 31		Connection 28		Connection 28							
	3	16d com (3 1/2 x .162)	3	16d box (3 1/2 x .135)	3	16d com (3 1/2 x .162)	3	16d com (3 1/2 x .162)	3	16d com (3 1/2 x .162)	5	3 x .131		
	4	3 x .131			4	3 x .131	4	16d box (3 1/2 x .135)	4	12d com (3 1/4 x .148)	6	8d com (2 1/2 x .131)		
					4	10d box (3 x .128)	4	3 x .131	4	10d com (3 x .148)	6	3 1/4 x .120		
							4	10d box (3 x .128)	4	16d box (3 1/2 x .135)	6	3 x .120		
									5	3 1/4 x .131				
Bridging to Joist (toe nail)	Connection 2				Connection 30		Connection 29							
	2	8d com (2 1/2 x .131)			2	8d com (2 1/2 x .131)	2	10d box (3 x .128)	2	16d com (3 1/2 x .162)	3	3 1/4 x .120		
	2	3 x .131			2	3 x .131			2	12d com (3 1/4 x .148)	3	3 x .120		
					2	10d box (3 x .128)			2	10d com (3 x .148)	3	8d box (2 1/2 x .113)		
									2	16d box (3 1/2 x .135)	3	2 3/8 x .113		
									2	3 1/4 x .131	3	6d com (2 x .113)		
									2	3 x .131	4	2 1/4 x .099		
									2	8d com (2 1/2 x .131)				
					each end		each end		each end		each end			

For **SI**: 1 inch = 25.4 mm

¹Alternative fastening requirements shown in this table have been evaluated as alternatives to the 2015 IBC and IRC and the 2012 IBC and IRC. They can be used under earlier editions of the IBC and IRC where the prescriptive fastening requirements are no worse than those shown in the table above for the 2015 and 2012 codes.

TABLE 11—SUMMARY OF ALTERNATIVE FASTENING DESIGNS RECOGNIZED IN TABLE 10^{1,2,3}

CONNECTION	NAIL SIZE (DIAMETER X LENGTH) (inches)												
	3 1/2 x 0.162	3 1/4 x 0.148	3 x 0.148	3 1/2 x 0.135	3 1/4 x 0.131	3 x 0.131	2 1/2 x 0.131	3 1/4 x 0.120	3 x 0.120	2 1/2 x 0.113	2 3/8 x 0.113	2 x 0.113	2 1/4 x 0.099
Wall Framing													
Double studs (face nail) Typical	24" o.c.	16" o.c.	16" o.c.	16" o.c.	16" o.c.	16" o.c.	8" o.c.	8" o.c.	8" o.c.				
At braced walls	16" o.c.	12" o.c.	12" o.c.	12" o.c.	12" o.c.	12" o.c.		8" o.c.	8" o.c.				
Abutting studs at corners and intersections Typical	12" o.c.	12" o.c.	12" o.c.	12" o.c.	8" o.c.	8" o.c.	8" o.c.	8" o.c.	8" o.c.				
At braced walls	12" o.c.	12" o.c.	12" o.c.	12" o.c.	12" o.c.	12" o.c.		8" o.c.	8" o.c.				
Built up header 2" to 2" w/ 1/2" spacer	12" o.c.	8" o.c.	8" o.c.	12" o.c.	8" o.c.	8" o.c.		8" o.c.	8" o.c.				
Continuous header to stud (toe nail)	3	4	4	4	4	4	4	5	5	6	6		
Double top plates to each other (face nail)	16" o.c.	12" o.c.	12" o.c.	12" o.c.	12" o.c.	12" o.c.	8" o.c.	8" o.c.	8" o.c.				
Top plate to top plate at end joint (lap splice) (each side of joint)	8	12	12	12	12	12							
For 2015 IRC Connection 13b	10	12	12										
Top plate overlap at corners and intersections (face nail)	2	3	3	3	3	3		4	4				
Sole plate to joist or blocking not at braced wall panels	16" o.c.	12" o.c.	12" o.c.	12" o.c.	12" o.c.	12" o.c.		8" o.c.	8" o.c.				
Sole Plate to joist or blocking at braced wall panel	2 @ 16" o.c.	3 @ 16" o.c.	3 @ 16" o.c.	3 @ 16" o.c.	4 @ 16" o.c.	4 @ 16" o.c.		4 @ 16" o.c.	5 @ 16" o.c.				
Top or sole plate to stud (end nail)	3	3	3	3	4	4	4	4	4				
Stud to top or sole plate (toe- nail)	3	4	4	4	4	4	4	5	5	6	6	6	
Diagonal bracing to stud/plate	2	2	2	2	2	2	2	3	3	3	3		4
Ceiling and Roof Framing													
Blocking Between Joists or Rafter to Top Plate (toe-nail) (each end)	3	3	3	3	3	3	3	4	4	5			
Ceiling joist to plate	3	3	3	3	3	3	3	4	4	5	5	5	
Ceiling joists laps over partitions (no thrust)	3	4	4	4	4	4		5	5				
Ceiling joist to parallel rafter	See Table 10												
Collar tie to rafter	3	3	3	4	4	4	5	5	5	6			
Roof rafter to plate (toe-nail) (+ connectors per IBC)	3	3	3	3	4	4	4	4	4				
Roof rafter to 2-by ridge beam (end-nail rafter to beam)	3	4	4	4	4	4		5	5				
Roof rafter to 2-by ridge beam (toe-nail rafter to beam)	3	4	4	4	5	5	5	6	6	6	6	6	
Jack rafter to hip (toe-nail)	3	4	4	4	5	5	5						
Jack rafter to hip (end nail)	3	4	4	4									
Floor Framing													
Joist to sill or girder (toe-nail)	3	3	3	3	3	3	3	4	4	5	5	5	
Rim joist to top plate (Toe-nail)	6" o.c.	6" o.c.	6" o.c.	6" o.c.	6" o.c.	6" o.c.	6" o.c.	4" o.c.	4" o.c.	4" o.c.	4" o.c.	3" o.c.	3" o.c.
Joist to band Joist (face nail)	3	4	4	4	4	4		6	6				
Built-up girders & beams Face-nail @ top and bottom PLUS # at ends or splice	24" o.c.	24" o.c.	24" o.c.	24" o.c.	24" o.c.	24" o.c.		16" o.c.	16" o.c.				
Ledger Strip	3	4	4	4	5	5	6	6	6				
Bridging to Joist (toe-nail)	2	2	2	2	2	2	2	3	3	3	3	3	4

For **SI**: 1 inch = 25.4 mm

¹Alternative fastening requirements shown in this table have been evaluated as alternatives to the 2015 IBC and IRC and the 2012 IBC and IRC. They can be used under earlier editions of the IBC and IRC where the prescriptive fastening requirements are no worse than those shown in the Table 10 for the 2015 and 2012.

²This fastening schedule applies to framing members having an actual thickness of 1 1/2" (nominal "2-by" lumber).

³Fastening schedule only applies to buildings of conventional wood frame construction where wind or seismic analysis is not required by the applicable code. In areas where wind or seismic analysis is required, required fastening must be determined by structural analysis.

APPENDIX A—REFERENCE DESIGN INFORMATION







A1.0 Reference Design Values for Nailed Connections:

A1.1 Source:

The equations shown here for nailed connections are found in the 2015, 2012 and 2005 ANSI/AWC National Design Specification (NDS) for Wood Construction.

A1.2 Reference Lateral Design Values:

Reference lateral design values are based on the yielding of connections as wood fibers are crushed and/or fastener shanks are bent. Reference lateral design values are determined from the lowest resulting value from six yield limit equations. These equations and depictions of these yield modes are shown below:

<p>For Mode I_m</p>  $Z = \frac{Dl_m F_{em}}{R_d}$	<p>For Mode III_m</p>  $Z = \frac{k_2 D l_m F_{em}}{(1 + 2R_e) R_d}$
<p>For Mode I_s</p>  $Z = \frac{Dl_s F_{es}}{R_d}$	<p>For Mode III_s</p>  $Z = \frac{k_3 D l_s F_{es}}{(2 + R_e) R_d}$
<p>For Mode II</p>  $Z = \frac{k_1 D l_s F_{es}}{R_d}$	<p>For Mode IV</p>  $Z = \frac{D^2}{R_d} \sqrt{\frac{2F_{em} F_{yb}}{3(1 + R_e)}}$

where:

$$K_1 = \frac{\sqrt{R_e + 2R_e^2(1 + R_t + R_t^2) + R_t^2 R_e^3} - R_e(1 + R_t)}{(1 + R_e)}$$

$$K_2 = -1 + \sqrt{2(1 + R_e) + \frac{2F_{yb}(1 + 2R_e)D^2}{3F_{em} l_m^2}}$$

$$K_3 = -1 + \sqrt{\frac{2(1 + R_e)}{R_e} + \frac{2F_{yb}(2 + R_e)D^2}{3F_{em} l_s^2}}$$

Z	= Reference lateral design value, lbf
R_e	= F_{em} / F_{es}
l_m	= Length of nail in main member (member holding point), inches
l_s	= Length of nail in side member, inches
F_{em}	= Dowel bearing strength of main member (member holding point), psi [See 2015 NDS Table 12.3.3 (2012 NDS Table 11.3.3, 2005 NDS Table 11.3.2)]
F_{es}	= Dowel bearing strength of side member, psi [See 2015 NDS Table 12.3.3 (2012 NDS Table 11.3.3, 2005 NDS Table 11.3.2)]
F_{yb}	= Bending yield strength of nail, psi (see Appendix B)
D	= Nail diameter, inch (When annularly threaded nails are used with threads at the shear plane, D = root diameter of threaded portion of nail)
R_d	= 2.2 for $D \leq 0.17$ ", 10D +0.5 for $0.17 < D < 0.25$
R_t	= l_m / l_s

A1.3 Reference Withdrawal Design Values:

For normal load duration (10 year), the reference withdrawal design value per inch of penetration of a smooth shank nail driven into the side grain (perpendicular to the fiber) of seasoned wood, or unseasoned wood which will remain wet, is calculated by the following formula:

$$W = 1380 G^{5/2} D$$

Where:

W = the reference withdrawal design value per lineal inch of penetration into the member holding the nail point.

D = the diameter of the nail shank in inches.

G = the assigned specific gravity of the wood found in Table A or the tables indicated below, as applicable:

$$\text{For SI: } W = 9.515 G^{5/2} D$$

Where:

W = the reference withdrawal design value per lineal millimeter of penetration into the member holding the nail point.

D = the diameter of the nail shank in millimeters.

G = the assigned specific gravity of the wood found in Table A or the tables indicated below, as applicable:

Code	Sawn Lumber	Wood Structural Panels
2015 IBC	2015 NDS Table 12.3.3A	2015 NDS Table 12.3.3B
2012 IBC	2012 NDS Table 11.3.3A	2012 NDS Table 11.3.3B
2009 and 2006 IBC	2005 NDS Table 11.3.2A	2005 NDS Table 11.3.2B

Ring shank and screw shank nails have reference withdrawal design values 10% greater than smooth shank nails of the same diameter.

TABLE A—ASSIGNED SPECIFIC GRAVITY AND DOWEL BEARING STRENGTH FOR SELECT WOOD SPECIES

SPECIES	SPECIFIC GRAVITY ¹	DOWEL-BEARING STRENGTH F_e (psi)	
		Nailed Connections	Stapled Connections
Aspen	0.39	2,950	3,850
Balsam Fir	0.36	2,550	3,450
Beech-birch-hickory	0.71	8,850	9,750
Coast Sitka Spruce	0.39	2,950	3,850
Douglas Fir-larch	0.50	4,650	5,550
Douglas Fir-south	0.46	4,000	4,900
Eastern Hemlock	0.41	3,200	4,100
Eastern Hemlock-tamarack	0.41	3,200	4,100
Eastern Hemlock-tamarack (north)	0.47	4,150	5,050
Eastern softwoods	0.36	2,550	3,450
Eastern Spruce	0.41	3,200	4,100
Eastern White Pine	0.36	2,550	3,450
Hem-Fir	0.43	3,500	4,400
Mountain Hemlock	0.47	4,150	5,050
Northern Pine	0.42	3,350	4,250
Northern Species	0.35	2,400	3,300
Northern White Cedar	0.31	1,900	2,800
Ponderosa Pine	0.43	3,500	4,400
Red Oak	0.67	7,950	8,850
Red Pine	0.44	3,650	4,550
Sitka Spruce	0.43	3,500	4,400
Southern Pine	0.55	5,550	6,450
Spruce-Pine-Fir	0.42	3,350	4,250
Western Cedars	0.36	2,550	3,450
Western Cedars (North)	0.35	2,400	3,300
Western Hemlock	0.47	4,150	5,050
Western White Pine	0.40	3,100	4,000
White Oak	0.73	9,300	10,200
Yellow Poplar	0.43	3,500	4,400
WOOD STRUCTURAL PANELS			
Plywood: Structural 1, Marine	0.50	4,650	5,550
Plywood: Other Grades	0.42	3,350	4,250
Oriented Strand Board All Grades	0.50	4,650	5,550

For **SI**: 1 psi = 6.89 kN/m².

¹Specific gravity based on weight and volume when oven dry.

A2.0 Reference Design Values for Stapled Connections:


A2.1 Source:

The equations shown here for nailed connections are found in the ICC-ES Acceptance Criteria for Staples (AC201) dated February 2013 (editorially revised February 2015).

A2.2 Reference Lateral Design Values:


Reference lateral design values for stapled connections must be determined using the minimum result from the equations shown below. These equations are relevant to wood-to-wood connections and to connections in which steel sheet metal is stapled to wood. The steel side member shall have sufficient thickness to prevent tearing of the steel sheet when loaded. Determination of dowel bearing strength of the sheet metal must consider Section I.2 of Appendix I of the NDS. Reference lateral design values are for normal load duration and must be multiplied by all applicable adjustment factors in accordance with the NDS.

Yield Mode I:



$$Z = \frac{2F_{es}l_s d}{K_D}$$

Yield Mode II:




$$Z = \frac{2dF_{em}}{K_D} \left(\frac{l_m}{1 + \frac{F_{es}}{F_{em}}} \right) \left[\sqrt{\frac{F_{es}}{F_{em}} + 2 \left(\frac{F_{es}}{F_{em}} \right)^2 \left[1 + \frac{l_s}{l_m} + \left(\frac{l_s}{l_m} \right)^2 \right] + \left(\frac{F_{es}}{F_{em}} \right)^3 \left(\frac{l_s}{l_m} \right)^2} - \frac{F_{es}}{F_{em}} \left(1 + \frac{l_s}{l_m} \right) \right]$$

Yield Mode III:



$$Z = \frac{2}{K_D} \left[\frac{-l_s F_{es} d}{2 \frac{F_{es}}{F_{em}} + 1} + F_{es} d \sqrt{\frac{l_s^2}{\left(2 \frac{F_{es}}{F_{em}} + 1 \right)^2} + \frac{l_s^2}{2 \frac{F_{es}}{F_{em}} + 1} + \frac{4M}{F_{es} d \left(2 \frac{F_{es}}{F_{em}} + 1 \right)}} \right]$$

Yield Mode IV:



$$Z = \frac{4F_{em} d}{K_D} \sqrt{\frac{M}{F_{em} d \left(1 + \frac{F_{em}}{F_{es}} \right)}}$$

where:

Z = Reference lateral design value for staple (2 legs), lbf.

F_{em} = Dowel bearing strength of the main member, psi = 900 psi + F_e from 2015 NDS Table 12.3.3 (2012 NDS Table 11.3.3, 2005 NDS Table 11.3.2) for $D < 1/4$ "

F_{es} = Dowel bearing strength of the side member, psi = 900 psi + F_e from 2015 NDS Table 12.3.3 (2012 NDS Table 11.3.3, 2005 NDS Table 11.3.2) for $D < 1/4$ "

d = Nominal wire diameter, inch, from Table 3.2.

M = Minimum staple bending moment, in-lbs, from Table 3.2.

l_s = Length of staple in side member, inches.

l_m = Length of staple in main member, inches, (minimum of 12D, where D is the nominal wire diameter from Table 3.2).

K_D = Diameter coefficient for staple connections = 2.2

A2.3 Reference Withdrawal Design Values:

Reference withdrawal design values (W) for staples installed in side grain of wood for use in must be calculated using the following equation:

$$W = 2760 G^{5/2} D$$

where:

W = Staple reference withdrawal design value, in pounds per inch of penetration in the member holding both staple legs.

G = the assigned specific gravity of the wood (see Table A and Section A1.3).

D = Nominal wire diameter, in inches, from Table 3.2.

$$\text{For SI: } W = 19.03 G^{5/2} D$$

where:

- W = Staple reference withdrawal design value, in Newtons per mm of penetration in the member holding both staple legs.
- G = The assigned specific gravity of the wood (see Table A and Section A1.3).
- D = Nominal wire diameter, in millimeters, from Table 3.2.

A3.0 DESIGN INFORMATION FOR DEFLECTION CALCULATIONS FOR DIAPHRAGMS AND SHEAR WALLS

A3.1 NAILS:

To determine the deflection of diaphragms and shear walls constructed as described in Tables 5 through 9, refer to Sections 4.2.2 and 4.3.2 of the AWC Special Design Provisions for Wind and Seismic (SDPWS), respectively. For 0.120 inch nails, use the G_s values shown in the SDPWS for the 6d common nails.

A3.2 STAPLES:

The staple deformation values shown in Table B must be used to determine diaphragm deflection in accordance with the IBC Section 2305.2 or shear wall deflection in accordance with the IBC Section 2305.3, as applicable.

TABLE B—STAPLE DEFORMATION VALUES, e_n , FOR USE IN HORIZONTAL DIAPHRAGM AND SHEAR WALL DEFLECTION ANALYSIS^{1,4}

Staple Gage	16		15		14	
Length (Inches)	1½	2	1¾	2½	2	2½
Load Per Fastener ² (Pounds)	Connection Deflection ³ (Inches)					
60	0.008	0.003	0.008	0.005	0.005	0.003
80	0.016	0.006	0.016	0.010	0.011	0.006
100	0.032	0.008	0.028	0.015	0.019	0.009
120	0.055	0.010	0.048	0.025	0.032	0.014
140	0.087	0.024	0.077	0.040	0.050	0.021
160	0.135	0.037	0.118	0.060	0.077	0.031
180	0.205	0.052	0.173	0.088	0.113	0.044
200	—	0.092	0.244	0.127	0.157	0.060
220	—	0.198	0.299	0.178	0.219	0.080
240	—	—	0.346	0.220	0.287	0.097

For **SI**: 1 inch = 25.4 mm 1 lbf = 4.45 N.

¹Increase deformation value by 20% for plywood grades other than Structural I sheathing.

²Load per fastener is the diaphragm's maximum shear per foot divided by the number of fasteners per foot at interior panel edges.

³Values must be doubled for unseasoned lumber.

⁴Values are for e_n in equations found in the IBC.

APPENDIX B
RECOGNIZED FASTENERS BY LISTEE

INDEX TO LISTEE PRODUCT DESCRIPTIONS:

LISTEE	PAGE NO.
American Fasteners Company Ltd. (American Fasteners Brand)	29
Building Material Distributors, Inc. (Master Fasteners Brand)	29
Falcon Fasteners Reg'd (Falcon Brand)	30
FASCO America, Inc. (Fasco, Fasco/Beck, Beck Fastener Group Brands)	31
Hitachi Koki U.S.A., Ltd. (Hitachi Brands)	32
Huttig Building Products (Huttig-Grip Brand)	32
JAACO Corporation (NailPro Brand)	33
Paslode, an Illinois Tool Works Company (Paslode, Lightning Strike, Duo-Fast Brands)	33
Peace Industries (Spotnails Brand)	34
PrimeSource Building Products (Grip-Rite, Fas'ners Unlimited, Fits Rite Brands)	34
Senco Brands, Inc. (Senco Brand)	35
Specialty Fastening Systems, Inc. (Specialty Fasteners Brand)	35
Stanley Black and Decker Inc. (BOSTITCH, DEWALT Brands)	36

General Notes for Appendix B:

1. For **SI**: 1 inch = 25.4 mm, 1 psi = 6.89 kPa.
2. Nails having the indicated diameter, shank type and finish type are recognized for any length. Staples having the indicated diameter and finish are recognized for any leg length greater than 1½ inches.
3. All nails are formed from carbon steel wire, unless designated in the tables below as stainless steel.
4. For a depiction of the various head styles, see Figure 1.

Terminology

LFRA = Lateral force resisting assembly: A diaphragm, shear wall or braced wall.

Head Area Ratio Requirements

- Y =6d = Meets the head requirements for use in sheathing attachment in LFRAs where a 6d common nail is prescribed in the code.
- Y =8d = Meets the head requirements for use in sheathing attachment in LFRAs where a 8d common nail is prescribed in the code.
- Y =10d = Meets the head requirements for use in sheathing attachment in LFRAs where a 10d common nail is prescribed in the code.
- Y =16d = Meets the head requirements for use in sheathing attachment in LFRAs where a 16d common nail is prescribed in the code.
- Y ### = Meets the head requirements for a 0.### diameter nail for use in sheathing attachment in shear walls and diaphragms in accordance with Tables 5 through 8 of this report.
- N = Not recognized for use in sheathing attachment in LFRAs.
- n/a = Nail size is not prescribed in the code or listed in the diaphragm tables in this report for use in LFRAs. Use of Metal Hardware Nails in LFRAs is outside the scope of this report.

Shank Type

- S = Smooth shank nail
- R = Ring shank nail
- Sc = Screw shank nail

Finish/ Coating Types

- X = The fasteners are carbon steel, "bright" (not galvanized or coated with a permanent proprietary coating), or galvanized to levels other than levels described by the HDG or EG designations below.
- HDG = Hot-dipped galvanized, complying with ASTM A153 Class D.
- EG = Electrogalvanized, complying with ASTM A641, Class 1.
- SS = Stainless Steel
- H = Hardened = Bending yield strength complies with Table S1.2 of ASTM F1667.
- HT = Bright, heat treated nail (may be the full nail or only a portion of the nail, such as the tip; compliance with Table S1.2 of F1667 not evaluated)
- HTEG = Nail heat treated and electrogalvanized
- P# = Denotes a proprietary coating recognized in an ICC-ES evaluation report, as follows:
P1 = ThickCoat™ recognized in ESR-1482.

AMERICAN FASTENERS COMPANY LTD.							
NAILS (Brand name: AMERICAN FASTENERS)							
TYPE OF COLLATION	NOMINAL DIAMETER (inch)	HEAD STYLE	RECOGNIZED FOR USE IN FRAMING	MEETS HEAD AREA RATIO REQUIREMENTS FOR USE IN LFRAs	SHANK TYPE	FINISH/ COATING	SPECIFIED BENDING YIELD STRENGTH F_{yb} (psi)
Plastic, paper	0.131	Full round	Y	Y =8d	S	X, HDG	100,000
	0.135		Y	Y 135	S	X, HDG	100,000
	0.148		Y	Y =10d	S	X, HDG	90,000
Metal Hardware Nails Designated as “Metal Connector Nail” on package labeling							
Paper	0.131	Full round	Y	n/a	S	X, HDG	100,000
	0.148		Y	n/a	S	X, HDG	90,000

BUILDING MATERIAL DISTRIBUTORS, INC.							
NAILS (Brand name: MASTER FASTENERS)							
TYPE OF COLLATION	NOMINAL DIAMETER (inch)	HEAD STYLE	RECOGNIZED FOR USE IN FRAMING	MEETS HEAD AREA RATIO REQUIREMENTS FOR USE IN LFRAs	SHANK TYPE	FINISH/ COATING	SPECIFIED BENDING YIELD STRENGTH F_{yb} (psi)
Wire, plastic, paper	0.113	Full Round	Y	Y =6d	S	X, HDG, EG	100,000
					R	X, EG	
	0.120		Y	Y 120	S, Sc	X	100,000
					R	X, EG	
	0.131		Y	Y =8d	S	X	100,000
					R	X, EG	
	0.135		Y	n/a	S	X	100,000
					S	X, HDG	
	0.148		Y	Y	R	X	
					Plastic	0.162	Y
Paper	0.113	Clipped	Y	Y =6d	S	X, HDG, EG	100,000
					R	X, EG	
	0.120		Y	Y 120	S, Sc	X	100,000
					R	X, EG	
	0.131		Y	Y	S	X, HDG, EG	100,000
					R	X, EG	

FALCON FASTENERS REG'D							
NAILS (Brand name: FALCON)							
TYPE OF COLLATION	NOMINAL DIAMETER (inch)	HEAD STYLE	RECOGNIZED FOR USE IN FRAMING	MEETS HEAD AREA RATIO REQUIREMENTS FOR USE IN LFRAs	SHANK TYPE	FINISH/ COATING	SPECIFIED BENDING YIELD STRENGTH F_{yb} (psi)
Wire	0.099	Full round	Y	n/a	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
Wire, plastic, paper	0.113		Y	Y =6d	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.120		Y	Y 120	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.131		Y	Y =8d	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.148		Y	Y =10d	S	X, HDG, SS, HT	90,000
					R	X, HDG, SS	
	0.162		Y	Y =16d	S	X, HDG, HT	90,000
Paper, wire	0.113	Notched	Y	Y =6d	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.120		Y	Y 120	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.131		Y	Y =8d	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
Paper	0.113	Clipped	Y	Y =6d	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.120		Y	Y 120	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.131		Y	Y =8d	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.148		Y	Y =10d	S	X, HDG, SS, HT	90,000
					R	X, HDG, SS	
Paper, wire	0.113	Offset	Y	Y =6d	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.120		Y	Y 120	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.131		Y	Y =8d	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
Paper	0.148	Y	Y =10d	S	X, HDG, SS, HT	90,000	
				R	X, HDG, SS		
Metal Hardware Nails Designated as “Metal Connector Nail” or “Joist Hanger Nail” on package labeling							
Paper	0.131	Full round**	Y	n/a	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
	0.148		Y		S	X, HDG, SS, HT	90,000
					R	X, HDG, SS	
	0.162		Y		S	X, HDG, HT	90,000
					R	X, HDG, SS	

**Head markings for Metal Hardware Nails:

'8' for 1 $\frac{1}{2}$ x 0.131; '8d' for 2 $\frac{1}{2}$ x 0.131; '10' for 1 $\frac{1}{2}$ x 0.148; '10L' for 2 $\frac{1}{2}$ x 0.148; '16' for 2 $\frac{1}{2}$ x 0.162

FASCO AMERICA, INC.							
NAILS (Brand names: FASCO, FASCO/BECK, BECK FASTENER GROUP)							
TYPE OF COLLATION	NOMINAL DIAMETER (inch)	HEAD STYLE	RECOGNIZED FOR USE IN FRAMING	MEETS HEAD AREA RATIO REQUIREMENTS FOR USE IN LFRAs	SHANK TYPE	FINISH/ COATING	SPECIFIED BENDING YIELD STRENGTH F_{yb} (psi)
Wire, plastic, paper	0.099	Full round	Y	n/a	S, R	X, HDG, EG,SS	100,000
					Sc	X, HDG, EG	
	0.113		Y	Y =6d	S, Sc	X, HDG, EG	100,000
					R	X, HDG, EG,SS	
	0.120		Y	Y 120	S	X, HDG, EG	100,000
					R, Sc	X, HDG, EG,SS	
	0.131		Y	Y =8d	S	X, HDG, EG	100,000
					R, Sc	X	
	0.135		Y	N	S, R, Sc	X	100,000
			0.148	Y	Y =10d	S, R	X, HDG, EG
Wire, plastic	0.162		Y	N	Sc	X, HDG	
					S, Sc	X, HDG	90,000
Plastic	0.180	Clipped	Y	n/a	S	X	80,000
	0.197		Y	n/a	S	X	80,000
	0.113		Y	Y =6d	S, Sc	X, HDG, EG	100,000
					R	X, HDG, EG,SS	
	0.120		Y	Y 120	S	X, HDG, EG	100,000
					R, Sc	X, HDG, EG,SS	
	0.131		Y	N	S	X, HDG, EG	100,000
					R, Sc	X	
	0.135	Y	N	S, R, Sc	X	100,000	
Wire, plastic, paper	0.113	Offset	Y	Y =6d	S, Sc	X, HDG, EG	100,000
					R	X, HDG, EG,SS	
	0.120		Y	N	S	X, HDG, EG	100,000
					R, Sc	X, HDG, EG,SS	
STAPLES (Brand names: FASCO, FASCO/BECK, BECK FASTENER GROUP)							
GAGE			NOMINAL CROWN WIDTH (inch)			FINISH/ COATING	
16			$\frac{7}{16}$			X	
15			$\frac{7}{16}$			X	
14			1			X	

HITACHI KOKI U.S.A., LTD.							
NAILS (Brand name: HITACHI)							
TYPE OF COLLATION	NOMINAL DIAMETER (inch)	HEAD STYLE	RECOGNIZED FOR USE IN FRAMING	MEETS HEAD AREA RATIO REQUIREMENTS FOR USE IN LFRAs	SHANK TYPE	FINISH/ COATING	SPECIFIED BENDING YIELD STRENGTH F_{yb} (psi)
Wire, plastic, paper	0.099	Full round	Y	n/a	S, R, Sc	X, EG, HDG	100,000
	0.113		Y	Y =6d	S	X, EG, HDG, SS, HT	100,000
					R	X, EG, HDG, SS	
					Sc	X, EG, HDG	
	0.120		Y	Y 120	S	X, EG, HDG, SS, HT	100,000
					R	X, EG, HDG, SS	
					Sc	X, EG, HDG	
	0.131		Y	Y =8d	S	X, EG, HDG, SS, HT	100,000
					R	X, EG, HDG, SS	
					Sc	X, HDG	
	0.148		Y	Y =10d	S	X, EG, HDG, SS, HT	90,000
					R	X, EG, HDG, SS	
					Sc	X, HDG	
	0.162		Y	N	S	X, EG, HDG	90,000
Paper	0.113	Clipped	Y	Y =6d	S, R, Sc	X, EG, HDG	100,000
	0.120		Y	Y 120	S, R, Sc	X, EG, HDG	100,000
	0.131		Y	Y =8d	S, R, Sc	X, EG, HDG	100,000
Wire, paper	0.113	Offset	Y	Y =6d	S, R, Sc	X, EG, HDG	100,000
	0.120		Y	Y 120	S, R, Sc	X, EG, HDG	100,000
	0.131		Y	Y =8d	S, R, Sc	X, EG, HDG	100,000
Metal Hardware Nails Designated “Metal Connector Nail” on package labeling							
Paper	0.148	Full round	Y	N	S	X, HT	90,000

HUTTIG BUILDING PRODUCTS							
NAILS (Brand name: HUTTIG-GRIP)							
TYPE OF COLLATION	NOMINAL DIAMETER (inch)	HEAD STYLE	RECOGNIZED FOR USE IN FRAMING	MEETS HEAD AREA RATIO REQUIREMENTS FOR USE IN LFRAs	SHANK TYPE	FINISH/ COATING	SPECIFIED BENDING YIELD STRENGTH F_{yb} (psi)
Plastic	0.113	Full round	Y	Y =6d	S, R, Sc	X	100,000
	0.120		Y	Y 120	S, R, Sc	X	100,000
	0.131		Y	Y =8d	S, R, Sc	X	100,000
	0.135		Y	Y 135	S	X	100,000
	0.148		Y	Y =10d	S, R, Sc	X	90,000
	0.162		Y	Y =16d	S	X	90,000

JAACO CORPORATION							
NAILS (Brand name: NAILPRO)							
TYPE OF COLLATION	NOMINAL DIAMETER (inch)	HEAD STYLE	RECOGNIZED FOR USE IN FRAMING	MEETS HEAD AREA RATIO REQUIREMENTS FOR USE IN LFRAs	SHANK TYPE	FINISH/ COATING	SPECIFIED BENDING YIELD STRENGTH F_{yb} (psi)
Wire, plastic	0.113	Full Round	Y	Y =6d	S	X	100,000
	0.120		Y	Y 120	S, R	X	100,000
Wire, plastic, paper	0.131		Y	Y =8d	S	X	100,000
Paper	0.148		Y	N	S	X	90,000
	0.162		Y	N	S	X	90,000
Metal Hardware Nails Designated “Joist Hanger Nail” on package labeling							
Paper	0.131	Full Round	Y	n/a	S	X	100,000
	0.148		Y	n/a	S	X	90,000
	0.162		Y	n/a	S	X	90,000

PASLODE, AN ILLINOIS TOOL WORKS COMPANY							
NAILS (Brand names: PASLODE, LIGHTNING STRIKE, DUO-FAST)							
TYPE OF COLLATION	NOMINAL DIAMETER (inch)	HEAD STYLE (Applicable Brand Name)	RECOGNIZED FOR USE IN FRAMING	MEETS HEAD AREA RATIO REQUIREMENTS FOR USE IN LFRAs	SHANK TYPE	FINISH/ COATING	SPECIFIED BENDING YIELD STRENGTH F_{yb} (psi)
Plastic, paper	0.113	Full Round	Y	Y =6d	S	X	100,000
				R	X, HDG		
	0.120		Y	Y 120	R, Sc	HDG	100,000
	0.131		Y	Y =8d	S	X, HDG	100,000
					Sc	HDG	
	0.148		Y	Y =10d	S	X	90,000
Paper	0.113	Offset (RounDrive™)	Y	Y =6d	S, R	X, HDG	100,000
	0.120		Y	Y 120	S	X	100,000
					R	HDG	
	0.131		Y	Y =8d	S	X, HDG	100,000
					R	HDG	
	0.135		Y	Y 135	S	X	100,000
Paper	0.120	Clipped (Paslode)	Y	Y 120	S, R	X	100,000
	0.131		Y	N	S, R	X	100,000
Paper	0.113	Clipped (Duo-Fast)	Y	Y 6d	S	X	100,000
					R	X, HDG	
	0.120		Y	Y 120	S	X	100,000
					R	HDG	
	0.131		Y	Y 8d	S	X, HDG	100,000

PEACE INDUSTRIES							
NAILS (Brand name: SPOTNAILS)							
TYPE OF COLLATION	NOMINAL DIAMETER (inch)	HEAD STYLE	RECOGNIZED FOR USE IN FRAMING	MEETS HEAD AREA RATIO REQUIREMENTS FOR USE IN LFRAs	SHANK TYPE	FINISH/ COATING	SPECIFIED BENDING YIELD STRENGTH F_{yb} (psi)
Wire	0.099	Full Round	Y	n/a	S	X, EG	100,000
					R	EG	100,000
					Sc	X	100,000
	0.113		Y	Y =6d	S, R	X	100,000
	0.120		Y	Y 120	S	X, EG	100,000
					R, Sc	X	100,000
0.131	Y		Y =8d	S	X	100,000	
Plastic	0.113		Y	Y =6d	S, Sc	X	100,000
					R	X, EG	100,000
	0.120				S, Sc	X	100,000
					R	EG	100,000
	0.131				Y	Y =8d	S
Paper	0.113	Clipped	Y	Y =6d	R	X	100,000
	0.120		Y	Y 120	R	HDG	100,000
	0.131		Y	Y =8d	S	X	100,000

PRIMESOURCE BUILDING PRODUCTS							
NAILS (Brand names: GRIP-RITE, FAS'NERS UNLIMITED, FITS RITE)							
TYPE OF COLLATION	NOMINAL DIAMETER (inch)	HEAD STYLE	RECOGNIZED FOR USE IN FRAMING	MEETS HEAD AREA RATIO REQUIREMENTS FOR USE IN LFRAs	SHANK TYPE	FINISH/ COATING	SPECIFIED BENDING YIELD STRENGTH F_{yb} (psi)
Wire	0.113	Full Round	Y	Y =6d	S, R, Sc	X	100,000
	0.120		Y	Y 120	S, R, Sc	X	100,000
	0.131		Y	Y =8d	S, R, Sc	X	100,000
Plastic	0.135	Full Round	Y	Y 135	S	X	100,000
	0.148		Y	Y =10d	S, R, Sc	X	90,000
	0.162		Y	Y =16d	S, R, Sc	X	90,000
Wire, paper	0.113	D head (clipped)	Y	Y =6d	S, R	X	100,000
	0.120		Y	Y 120	S, R	X	100,000
	0.131		Y	Y =8d	S, R	X	100,000
Wire, paper	0.113	Offset	Y	Y =6d	S	X	100,000
	0.120		Y	Y 120	S	X	100,000
	0.131		Y	Y =8d	S	X	100,000

SENCO BRANDS, INC.							
NAILS (Brand name: SENCO)							
TYPE OF COLLATION	NOMINAL DIAMETER (inch)	HEAD STYLE	RECOGNIZED FOR USE IN FRAMING	MEETS HEAD AREA RATIO REQUIREMENTS FOR USE IN LFRAs	SHANK TYPE	FINISH/ COATING	SPECIFIED BENDING YIELD STRENGTH F_{yb} (psi)
Plastic, wire	0.113	Full Round	Y	Y =6d	S, R	X, EG, HDG	100,000
	0.120		Y	Y 120	S, Sc	X, EG, HDG	100,000
	R				X, HDG		
Plastic, paper, wire	0.131		Y	Y =8d	S	X, EG, HDG	100,000
					R	X, HDG	
	0.135		Y	Y 135	S	X	100,000
Plastic, paper	0.148	Y	Y =10d	S	X, HDG	90,000	
Paper	0.162	Y	Y =16d	S	X, HDG, HT	90,000	
Paper	0.113	Clipped	Y	Y =6d	S, R	X, EG, HDG	100,000
	0.120		Y	Y 120	S	X, EG, HDG	100,000
					R	X, HDG	
	0.131		Y	Y =8d	S	X, EG, HDG	100,000
R		X, HDG					
0.135	Y	Y 135	S	X	100,000		
Paper	0.113	Offset	Y	Y =6d	S, R	X, HDG	100,000
	0.120		Y	Y 120	S, R	X, HDG	100,000
	0.131		Y	Y =8d	S, R	X, HDG	100,000
STAPLES (Brand name: SENCO)							
GAGE			NOMINAL CROWN WIDTH (inch)			FINISH/ COATING	
14			$\frac{7}{16}$			X	
15			$\frac{7}{16}$			X, EG	
16			$\frac{7}{16}$, 1			X, EG	

SPECIALTY FASTENING SYSTEMS, INC.							
NAILS (Brand names: SPECIALTY NAIL CO., SPECIALTY FASTENERS)							
TYPE OF COLLATION	NOMINAL DIAMETER (inch)	HEAD STYLE	RECOGNIZED FOR USE IN FRAMING	MEETS HEAD AREA RATIO REQUIREMENTS FOR USE IN LFRAs	SHANK TYPE	FINISH/ COATING	SPECIFIED BENDING YIELD STRENGTH F_{yb} (psi)
Plastic, paper	0.099	Full round	Y	n/a	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.113		Y	Y =6d	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.120		Y	Y 120	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.131		Y	Y =8d	S	X, HDG, SS, HT	100,000
					R	X, HDG, SS	
					Sc	X, HDG	
	0.148		Y	Y =10d	S	X, HDG, SS, HT	90,000
					R	X, HDG, SS	
	0.162		Y	Y =16d	S	X, HDG, HT	90,000

STANLEY BLACK AND DECKER INC.							
NAILS (Brand name: BOSTITCH, DEWALT)							
TYPE OF COLLATION	NOMINAL DIAMETER (inch)	HEAD STYLE	RECOGNIZED FOR USE IN FRAMING	MEETS HEAD AREA RATIO REQUIREMENTS FOR USE IN LFRAs	SHANK TYPE	FINISH/ COATING	SPECIFIED BENDING YIELD STRENGTH F_{yb} (psi)
Wire, plastic	0.099	Full Round	Y	n/a	S, R, Sc	X, HDG, P1(B) ¹	100,000
	0.113		Y	Y =6d	S, R	X, HDG, EG, P1	100,000
			Y	Y =6d	Sc	X, HDG, P1(B)	
	0.120		Y	Y 120	S, R	X, HDG, EG, P1	100,000
			Y	Y 120	Sc	X, HDG, P1(B)	
	0.131		Y	Y =8d	S	X, HDG, EG, P1	100,000
			Y	Y =8d	R	X, HDG, EG	
	Y		Y =8d	Sc	X, HDG, P1(B)		
	0.135		Y	Y 135	S	X	100,000
0.148	Y	Y =10d	S, Sc	X	90,000		
0.162	Y	N	S	X, P1(B)	90,000		
Paper	0.113	Clipped	Y	Y =6d	S, R	X, HDG, EG, P1	100,000
			Y	Y =6d	Sc	X, HDG, P1	
	0.120		Y	Y 120	S, R	X, HDG, EG, P1	100,000
			Y	Y 120	Sc	X, HDG, P1	
	0.131		Y	Y =8d	S, R	X, HDG, EG, P1	100,000
			Y	Y =8d	Sc	X, HDG, P1	
Wire, paper	0.113	Offset	Y	Y =6d	S, R	X, HDG, EG, P1	100,000
			Y	Y =6d	Sc	X, HDG, P1	
	0.120		Y	Y 120	S, R	X, HDG, EG, P1	100,000
			Y	Y 120	Sc	X, HDG, P1	
	0.131		Y	Y =8d	S, R	X, HDG, EG, P1	100,000
			Y	Y =8d	Sc	X, HDG, P1	
Wire	0.113	Notched	Y	Y =6d	S, R	X, HDG, EG, P1	100,000
			Y	Y =6d	Sc	X, HDG, P1	
	0.120		Y	Y 120	S, R	X, HDG, EG, P1	100,000
			Y	Y 120	Sc	X, HDG, P1	
	0.131		Y	Y =8d	S, R	X, HDG, EG, P1	100,000
			Y	Y =8d	Sc	X, HDG, P1	
Metal Hardware Nails Designated as “Metal Connector Nail” on package labeling**							
Paper, plastic	0.131	Full Round**	Y	n/a	S	X, P1, H	100,000
	0.148		Y	n/a	S	X, P1, H	90,000
	0.162		Y	n/a	S	X, P1, H	90,000
**Head markings for metal hardware nails: 'B1' for 1½ x 0.131; 'B2' for 2½ x 0.131; 'B3' for 1½ x 0.148; 'B4' for 2½ x 0.148; 'B5' for 2½ x 0.162							
STAPLES (Brand name: BOSTITCH, DEWALT)							
GAGE			NOMINAL CROWN WIDTH (inch)			FINISH/COATING	
16			7/16			X, EG	
16			½			X, EG	
16			1			X, EG	
15			½			X	

¹P1(B) means that the P1 coating is only available under the BOSTITCH Brand Name.