



Most Widely Accepted and Trusted

ICC-ES Evaluation Report

ESR-2783

ICC-ES | (800) 423-6587 | (562) 699-0543 | www.icc-es.org

Reissued 09/2017
This report is subject to renewal 09/2019.

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION
SECTION: 07 65 00—FLEXIBLE FLASHING

REPORT HOLDER:

MFM BUILDING PRODUCTS CORPORATION

**POST OFFICE BOX 340
COSHOCKTON, OHIO 43812**

EVALUATION SUBJECT:

**SUBSEAL 40 AND SUBSEAL 60, FUTUREFLASH™, WINDOWWRAP® PSX-20,
WINDOWWRAP® WHITE AND WINDOWWRAP® POWERBOND™ FLASHING**



Look for the trusted marks of Conformity!

“2014 Recipient of Prestigious Western States Seismic Policy Council (WSSPC) Award in Excellence”



ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.



ICC-ES Evaluation Report

ESR-2783

Reissued September 2017

This report is subject to renewal September 2019.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION

Section: 07 65 00—Flexible Flashing

REPORT HOLDER:

MFM BUILDING PRODUCTS CORPORATION
POST OFFICE BOX 340
COSHOCKTON, OHIO 43812
(740) 622-2645
www.mfmbp.com

EVALUATION SUBJECT:

SUBSEAL 40 AND SUBSEAL 60, FUTUREFLASH™, WINDOWWRAP® PSX-20, WINDOWWRAP® WHITE AND WINDOWWRAP® POWERBOND™ FLASHING

ADDITIONAL LISTEE:

HUTTIG BUILDING PRODUCTS
555 MARYVILLE UNIVERSITY DRIVE
SUITE 400
ST. LOUIS, MISSOURI 63141

Product: Huttig-Grip™ (Same as WindowWrap® PSX-20)

1.0 EVALUATION SCOPE

Compliance with the following codes:

- 2015, 2012, 2009 and 2006 *International Building Code*® (IBC)
- 2015, 2012, 2009 and 2006 *International Residential Code*® (IRC)

Properties evaluated:

- Physical properties
- Water resistance

2.0 USES

2.1 FutureFlash:

FutureFlash is used as a mechanically attached flashing for wall penetrations under 2015, 2012 and 2009 IBC Section 1405.4 (2006 IBC Section 1405.3) or 2012, 2009 and 2006 IRC R703.8.

2.2 WindowWrap® PSX-20, WindowWrap® White and WindowWrap® PowerBond™:

WindowWrap products are self-adhering flashing for wall penetrations under 2015, 2012 and 2009 IBC Section

1405.4 (2006 IBC Section 1405.3), or 2015 IRC Section R703.4 (2012, 2009 and 2006 IRC Section R703.8).

2.3 SubSeal 40 and SubSeal 60:

SubSeal 40 and SubSeal 60 flexible flashing are self-adhering flashing for wall penetrations under 2015, 2012 and 2009 IBC Section 1405.4 (2006 IBC Section 1405.3), or 2015 IRC Section R703.4 (2012, 2009 and 2006 IRC Section R703.8).

3.0 DESCRIPTION

3.1 FutureFlash:

FutureFlash is a three-ply, composite sheet-type membrane consisting of a gray-colored, polyethylene, outer-surface film; a rubberized asphalt core; and a polyester inner-surface film. The membrane is nominally 26 mils [0.026-inch (0.66 mm)] thick and is available in 75-foot-long (22 860 mm) rolls having multiple widths.

3.2 WindowWrap® PSX-20, WindowWrap® White and WindowWrap® PowerBond™:

WindowWrap products are self-adhering tape consisting of a multilayer polymer film coated with a rubberized asphalt formed to a nominal thickness of 25 mils [0.025 inch (0.64 mm)]. A silicone-coated release paper protects the adhesive surface and is removed prior to installation. The tape is available in rolls of various widths and length up to 100 feet. The WindowWrap products comply with AAMA 711 for self-adhering flashing.

3.3 SubSeal 40:

SubSeal 40 is a self-adhering sheet-type membrane, consisting of a multilayer polyethylene film coated with formulated rubberized asphalt formed to a minimum total thickness of 40 mils [0.04 inch (1.0 mm)]. A silicone-coated release paper protects the adhesive surface, and is removed prior to installation. The membrane is available in 75-foot-long (22 860 mm) rolls having multiple widths.

3.4 SubSeal 60:

SubSeal 60 is a self-adhering sheet-type membrane, consisting of a multilayer polyethylene film coated with formulated rubberized asphalt formed to a minimum total thickness of 60 mils [0.06-inch (1.5 mm)]. A silicone-coated release paper protects the adhesive surface, and is removed prior to installation. The membrane is available in 60-foot-long (18 288 mm) rolls having multiple widths.

4.0 INSTALLATION

4.1 FutureFlash:

FutureFlash must be mechanically attached, in accordance with the manufacturer's published installation instructions,

in shingle-fashion, to prevent entry of moisture into the wall cavity or penetration of water to the building structural framing components in accordance with 2015, 2012 and 2009 IBC Section 1405.4 (2006 IBC Section 1405.3), or 2012, 2009 and 2006 IRC R703.8, as applicable.

4.2 WindowWrap® PSX-20, WindowWrap® White and WindowWrap® PowerBond™:

The WindowWrap products must be applied to substrates that are dry and free of dirt, dust or other foreign matter that would inhibit proper adhesion. The WindowWrap products must be applied when the ambient air and surface temperatures are 35°F (1.7°C) or higher. Installation of the tape as a flashing material is limited to use with OSB, wood, steel, aluminum and vinyl substrates. The tape is applied around penetrations in the manner described in the manufacturer's published installation instructions.

4.3 SubSeal 40 and SubSeal 60:

The SubSeal 40 and SubSeal 60 products must be applied to substrates that are dry and free of dirt, dust or other foreign matter that would inhibit proper adhesion. The SubSeal 40 and SubSeal 60 products must be applied when the ambient air and surface temperatures are 35°F (1.7°C) or higher. Installation of the self-adhering sheet type membrane as a flashing material is limited to use with OSB, wood, steel, aluminum and vinyl substrates. The tape is applied around penetrations in the manner described in the manufacturer's published installation instructions.

5.0 CONDITIONS OF USE

The FutureFlash™, WindowWrap®, SubSeal 40 and SubSeal 60 products described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

5.1 Installation must comply with this report, the manufacturer's published application instructions and the applicable code. In the event of a conflict between the manufacturer's published instructions and this report, the more restrictive governs.

5.2 Installation of FutureFlash, WindowWrap, SubSeal 40 and SubSeal 60 is limited to buildings of Type V-B construction (IBC) and construction permitted by the IRC. Under the 2015 IBC, the flashing products may be installed in Types I, II, III or IV construction, as indicated in the 2015 IBC Section 1403.5.

5.3 The WindowWrap and SubSeal products are limited to installation on those substrates stated in Sections 4.2 and 4.3.

5.4 FutureFlash shall be limited to application on vertical walls.

5.5 FutureFlash is not recognized for use as pan flashing or through-wall flashing.

6.0 EVIDENCE SUBMITTED

Data in accordance with the ICC-ES Acceptance Criteria for Flexible Flashing Materials (AC148), dated April 2015.

7.0 IDENTIFICATION

Each carton is identified with a label bearing the product name (FutureFlash, WindowWrap, Huttig-Grip, SubSeal 40 or SubSeal 60), the production date, the manufacturer's name (MFM Building Products Corporation) or additional listee name (Huttig Building Products) and address, and the evaluation report number (ESR-2783).