

ICC-ES Evaluation Report

ESR-1150

Reissued March 1, 2009

This report is subject to re-examination in two years.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 07—THERMAL AND MOISTURE PROTECTION
Section: 07310—Shingles
REPORT HOLDER:
COPPER RIVER SHAKE AND SHINGLE LTD.
9450 - 287 STREET
MAPLE RIDGE, BRITISH COLUMBIA V2W 1L1
CANADA
(604) 309-4582
EVALUATION SUBJECT:
WESTERN RED CEDAR SHAKES AND SHINGLES
1.0 EVALUATION SCOPE
Compliance with the following codes:

- 2006 *International Building Code*® (IBC)
- 2006 *International Residential Code*® (IRC)
- 1997 *Uniform Building Code*™ (UBC)

Property evaluated:

Roof covering

2.0 USES

The Copper River Shake and Shingle Ltd. western red cedar shakes and shingles are wood roof covering materials for use where the codes permit nonclassified (IBC and IRC) or nonrated (UBC) roof covering.

3.0 DESCRIPTION

Western red cedar shakes (nonpreservative-treated) are manufactured in accordance with the grading rules specified in IBC Section 1507.9.5, IRC Section R905.8.5 and UBC Standard 15-3. The western red cedar shingles (nonpreservative-treated) are manufactured in accordance with the grading rules specified in IBC Section 1507.8.4, IRC Section R905.7.4 and UBC Standard 15-4.

4.0 INSTALLATION

The western red cedar shakes shall be installed in accordance with IBC Section 1507.9, IRC Section R905.8 or UBC Table 15-B-2, as applicable. The western red cedar shingles shall be installed in accordance with IBC Section 1507.8, IRC Section R905.7 or UBC Table 15-B-2, as applicable.

5.0 CONDITIONS OF USE

The Copper River Shake and Shingle Ltd. western red cedar shakes and shingles described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 Products shall be identified as shown in Figure 1 of this report.
- 5.2 Products shall be manufactured at 9550 - 228 Street, Maple Ridge, British Columbia, Canada, with inspections by Underwriters Laboratories Inc. (AA-668).
- 5.3 Products shall be installed as noted in Section 4.0 of this report.

6.0 EVIDENCE SUBMITTED

- 6.1 Quality control manual.
- 6.2 Label facsimiles.
- 6.3 Inspection procedures of the inspection agency.

7.0 IDENTIFICATION

Each bundle of shakes or shingles shall be labeled as noted in Figure 1 of this report. Each pallet shall have a pallet release tag showing the name of the inspection agency (Underwriters Laboratories Inc.), mill name (Copper River Shake and Shingle), mill address, packing date, product type, evaluation report number (ESR-1150) and the dated signature of the responsible person releasing the material.


FIGURE 1

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, Inc., express or implied, as to any finding or other matter in this report, or as to any product covered by the report.